

Allendale Elementary School - Sampled 7/21/16			
CustomerSampleNumber	Description	Lead Result	Units
00300-610-S	Sink in Classroom 610	12.3	ppb
00300-610-SWB	Sink with Bubblers in Classroom 610	0.4	ppb
00300-609-S	Sink Classroom 609	16.2	ppb
00300-609-SWB	Sink with Bubblers in Classroom 609	4.7	ppb
00300-507-S	Sink in Classroom 507	12.2	ppb
00300-507-SWB	Sink with Bubblers in Classroom 507	5.6	ppb
00300-506-S	Sink in Classroom 506	106.7	ppb
00300-506-SWB	Sink with Bubblers in Classroom 506	7.2	ppb
00300-505-S	Sink in Classroom 505	7.5	ppb
00300-505-SWB	Sink with Bubblers in Classroom 505	5.7	ppb
00300-510H-DF	Hallway Drinking Fountain across from Classroom 505	8.5	ppb
00300-504-S	Sink in Classroom 504	22.0	ppb
00300-504-SWB	Sink with Bubblers in Classroom 504	3.2	ppb
00300-503-S	Sink in Classroom 503	10.2	ppb
00300-503-SWB	Sink with Bubblers in Classroom 503	2.0	ppb
00300-608-S	Sink in Music Room	14.0	ppb
00300-608-SWB	Sink with Bubblers in Music Room	2.8	ppb
00300-606-S1	Art Room Sink	7.9	ppb
00300-606-S2	Art Room Sink	44.7	ppb
00300-606-S3	Art Room Sink	24.8	ppb
00300-601-S	Sink in Library	44.4	ppb
00300-601-SWB	Sink with Bubblers in Library	8.5	ppb
00300-402-S	Sink in Classroom 402	17.8	ppb
00300-402-SWB	Sink with Bubblers in Classroom 402	7.3	ppb
00300-403-S	Sink in Classroom 403	34.4	ppb
00300-403-SWB	Sink with Bubblers in Classroom 403	9.7	ppb
00300-404-S	Sink in Classroom 404	25.9	ppb
00300-404-SWB	Sink with Bubblers in Classroom 404	3.6	ppb
00300-412H-DF	Hallway Drinking Fountain across from Classroom 404	13.9	ppb
00300-405-S	Sink in Classroom 405	24.7	ppb
00300-405-SWB	Sink with Bubblers in Classroom 405	4.2	ppb
00300-406-S	Sink in Classroom 406	4.4	ppb
00300-406-SWB	Sink with Bubblers in Classroom 406	4.2	ppb
00300-401-S	Sink in Computer Room	27.6	ppb
00300-401-SWB	Sink with Bubblers in Computer Room	1.8	ppb
00300-602-S	Sink in Library Work Room	123.6	ppb
00300-602-SWB	Sink with Bubblers in Library Work Room	19.2	ppb
00300-407-S	Sink in Classroom 407	29.8	ppb
00300-407-SWB	Sink with Bubblers in Classroom 407	8.3	ppb
00300-302-S	Sink in Conference Room	28.8	ppb
00300-302-SWB	Sink with Bubblers in Conference Room	9.7	ppb
00300-301-S	Sink in Teacher's Lounge	0.6	ppb

00300-101-S	Sink in Clinic	2.0	ppb
00300-101H-DF	Hallway Drinking Fountain near Main Offices	4.6	ppb
00300-108-S	Sink in Kindergarten Classroom 108	3.4	ppb
00300-108-SWB	Sink with Bubbler in Kindergarten Classroom 108	0.7	ppb
00300-201-DF	Drinking Fountain in Cafeteria	8.0	ppb
00300-211-DF	Drinking Fountain in Gym	6.0	ppb
00300-204-S1	Food Service Sink-Food Prep	17.4	ppb
00300-204-S2	Food Service Sink-Hand Sink	102.4	ppb
00300-204-S3	Food Service Sink-Hand Sink	29.0	ppb
00300-204-S5	Food Service Sink-Rinse/Wash	5.8	ppb
00300-204-S4	Food Service Sink-Sprayer	2.8	ppb
00300-204-S6	Food Service Sink-Rinse/Wash	20.3	ppb
00300-REC-123-DF	Drinking Fountain in TEMP REC-123	2.0	ppb