

Bear Creek K-8 - Sampled 9/29/16			
CustomerSampleNumber	Description	Lead Result	Units
04000-1119-S	Sink in Clinic	0.3	ppb
04000-1126-S	Sink in Work Room 1126	0.3	ppb
04000-1129-S	Sink in Conference Room across from AP Offices	0.5	ppb
04000-1134-S	Sink in Teacher's Lounge	0.1	ppb
04000-1133-S	Sink in Teacher Planning Multi-Use Room 1133	0.3	ppb
04000-1109-S	Sink in Tech Lab #2 across from Counseling Office	0.7	ppb
04000-1109-SWB	Sink with Bubbler in Tech Lab #2 across from Counseling Office	0.7	ppb
04000-1100-S	Sink in Classroom 1100	0.1	ppb
04000-1013-SWB	Sink with Bubbler in Classroom 1013	0.2	ppb
04000-1013H-DFL	Hallway Drinking Fountain next to Resource Room 1011/Left	0.2	ppb
04000-1013H-DFR	Hallway Drinking Fountain next to Resource Room 1011/Right	0.2	ppb
04000-1010-SWB	Sink with Bubbler in Classroom 1010	0.1	ppb
04000-1007-SWB	Sink with Bubbler in Kindergarten Classroom 1007	0.2	ppb
04000-1005-SWB	Sink with Bubbler in Kindergarten Classroom 1005	0.1	ppb
04000-1001-SWB	Sink with Bubbler in Kindergarten Classroom 1001	0.2	ppb
04000-1018-SWB	Sink with Bubbler in Classroom 1018	0.3	ppb
04000-1017-SWB	Sink with Bubbler in Classroom 1017	0.3	ppb
04000-1016-SWB	Sink with Bubbler in Classroom 1016	0.1	ppb
04000-1015-SWB	Sink with Bubbler in Classroom 1015	0.2	ppb
04000-1014-SWB	Sink with Bubbler in Classroom 1014	0.2	ppb
04000-1136-SWB	Sink with Bubbler in Classroom 1136	0.1	ppb
04000-1137-SWB	Sink with Bubbler in Classroom 1137	0.1	ppb
04000-1138-SWB	Sink with Bubbler in Classroom 1138	0.2	ppb
04000-1139-SWB	Sink with Bubbler in Classroom 1139	0.1	ppb
04000-1039H-DFL	Hallway Drinking Fountain outside of Gym/Left	0.2	ppb
04000-1039H-DFR	Hallway Drinking Fountain outside of Gym/Right	0.4	ppb
04000-1143-S1	Sink in Art Room 1143	0.2	ppb
04000-1200-S2	Sink in Art Room 1200	0.5	ppb
04000-1201-S	Sink in Concession Area	4.3	ppb
04000-1203-SWB	Sink with Bubbler in Classroom 1203	0.3	ppb
04000-1204-SWB	Sink with Bubbler in Classroom 1204	0.2	ppb
04000-1205-SWB	Sink with Bubbler in Classroom 1205	0.1	ppb
04000-1206-S	Sink in Classroom 1206	14.4	ppb
04000-1206-SWB	Sink with Bubbler in Classroom 1206	0.2	ppb
04000-1207-SWB	Sink with Bubbler in Classroom 1207	0.2	ppb
04000-1208-SWB	Sink with Bubbler in Classroom 1208	0.2	ppb
04000-1209-SWB	Sink with Bubbler in Classroom 1209	0.2	ppb
04000-1210-SWB	Sink with Bubbler in Classroom 1210	0.1	ppb
04000-1211-S	Sink in Classroom 1211	0.3	ppb
04000-1211-SWB	Sink with Bubbler in Classroom 1211	0.2	ppb
04000-1212-SWB	Sink with Bubbler in Classroom 1212	0.2	ppb
04000-1216-SWB	Sink with Bubbler in Classroom 1216	0.1	ppb
04000-1217-SWB	Sink with Bubbler in Classroom 1217	0.2	ppb
04000-1225-S	Sink in Planning Room 1225	0.4	ppb
04000-1233H-DFL	Hallway Drinking Fountain across from Cafeteria/Left	0.2	ppb
04000-1233H-DFR	Hallway Drinking Fountain across from Cafeteria/Right	0.2	ppb
04000-1400-S	Sink in Music Room 1400	2.5	ppb
04000-1400-SWB	Sink with Bubbler in Music Room 1400	0.1	ppb
04000-1408-SWB	Sink with Bubbler in Music Room 1408	0.1	ppb

04000-1408-S	Sink in Music Room 1408	0.3	ppb
04000-1418-S1	Food Service Sink-Hand Sink	1.0	ppb
04000-1418-S2	Food Service Sink-Food Prep	3.8	ppb
04000-1418-S3	Food Service Sink-Sprayer	15.2	ppb
04000-1412-S1	Food Service Sink-Hand Sink	1.6	ppb
04000-1412-S2	Food Service Sink-Sprayer	4.2	ppb
04000-1412-S3	Food Service Sink-Wash/Rinse	8.9	ppb
04000-1412-S4	Food Service Sink-Rinse/Sanitize	8.7	ppb
04000-1309H-DFL	Hallway Drinking Fountain outside of Gym/Left	0.3	ppb
04000-1309H-DFR	Hallway Drinking Fountain outside of Gym/Right	0.6	ppb
04000-1409-S	Sink in Instrument/Band Room	0.4	ppb
04000-1409-SWB	Sink with Bubbler in Instrument/Band Room	0.4	ppb
04000-1231H-DFL	Hallway Drinking Fountain outside of Speech Room 1231/Left	0.3	ppb
04000-1231-DFR	Hallway Drinking Fountain outside of Speech Room 1231/Right	0.3	ppb
04000-1300-S	Sink in Library Work Room	0.4	ppb
04000-1310-IM	Ice Machine in Weight Room	0.3	ppb
04000-1112-S	Sink in Resource Room 1112	0.3	ppb
04000-1112-SWB	Sink with Bubbler in Resource Room 1112	0.4	ppb
04000-2120-SWB	Sink with Bubbler in Foreign Language Room 2120	0.2	ppb
04000-2200-SWB	Sink with Bubbler in Foreign Language Room 2200	0.1	ppb
04000-2201H-DFL	Hallway Drinking Fountain outside of Resource Room 2201/Left	0.2	ppb
04000-2201H-DFR	Hallway Drinking Fountain outside of Resource Room 2201/Right	0.1	ppb
04000-2201-SWB	Sink with Bubbler in Classroom 2201	0.2	ppb
04000-2201-S	Sink in Classroom 2201	0.4	ppb
04000-2203-SWB	Sink with Bubbler in Classroom 2203	<0.1 *	ppb
04000-2204-SWB	Sink with Bubbler in Classroom 2204	0.1	ppb
04000-2205-SWB	Sink with Bubbler in Classroom 2205	1.1	ppb
04000-2206-SWB	Sink with Bubbler in Classroom 2206	0.2	ppb
04000-2207-SWB	Sink with Bubbler in Classroom 2207	0.2	ppb
04000-2208-SWB	Sink with Bubbler in Classroom 2208	0.1	ppb
04000-2209-SWB	Sink with Bubbler in Classroom 2209	0.1	ppb
04000-2210-SWB	Sink with Bubbler in Classroom 2210	0.2	ppb
04000-2211-SWB	Sink with Bubbler in Classroom 2211	0.4	ppb
04000-2225-SWB	Sink with Bubbler in Classroom 2225	0.2	ppb
04000-2226-SWB	Sink with Bubbler in Classroom 2226	0.2	ppb
04000-2220-S	Sink in Planning Room 2220	0.4	ppb
04000-2108-S	Sink in Planning Room 2108	0.4	ppb
04000-2107-S	Sink in Resource Room 2107	0.4	ppb
04000-2107-SWB	Sink with Bubbler in Resource Room 2107	0.9	ppb
04000-2105H-DFL	Hallway Drinking Fountain across from Classroom 2117/Left	0.2	ppb
04000-2105H-DFR	Hallway Drinking Fountain across from Classroom 2117/Right	0.4	ppb
04000-2101-SWB	Sink with Bubbler in Classroom 2101	0.3	ppb
04000-2100-SWB	Sink with Bubbler in Classroom 2100	0.2	ppb
04000-2003-S	Sink in Classroom 2003	0.4	ppb
04000-2003-SWB	Sink with Bubbler in Classroom 2003	0.5	ppb
04000-2000-SWB	Sink with Bubbler in Classroom 2000	0.1	ppb
04000-2006-SWB	Sink with Bubbler in Classroom 2006	0.2	ppb
04000-2005-SWB	Sink with Bubbler in Classroom 2005	0.1	ppb
04000-2118-SWB	Sink with Bubbler in Classroom 2118	0.2	ppb

* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.