

Belmar Elementary School - Sampled 6/24/16				Resampled 5/4/17	
SampleNumber	Description	Lead Result	Units	Lead Result	Unit
04500-105-S	Sink in Cafeteria	9.7	ppb	6.9	ppb
04500-105-DF	Drinking Fountain in Cafeteria	2.4	ppb	4.0	ppb
04500-116-S1	Food Service-Rinse Sink	9.1	ppb	6.9	ppb
04500-116-S2	Food Service-Wash Sink	4.2	ppb	1.6	ppb
04500-116-S3	Food Service-Hand Sink	5.6	ppb		
04500-116-S4	Food Service-Wash Sink	5.2	ppb	2.7	ppb
04500-116-S5	Food Service-Rinse Sink	5.5	ppb	2.6	ppb
04500-128-S	Sink in Conference Room 128	0.7	ppb	0.3	ppb
04500-129-S	Sink in Teacher's Lounge	0.6	ppb	0.3	ppb
04500-135-SWB	Sink with Bubbler in Classroom 135	0.8	ppb	0.5	ppb
04500-135-S	Sink in Classroom 135	0.7	ppb		
04500-136-SWB	Sink with Bubbler in Classroom 136	1.0	ppb	0.3	ppb
04500-136-S	Sink in Classroom 136	0.5	ppb		
04500-137-S	Sink in Classroom 137	0.4	ppb		
04500-137-SWB	Sink with Bubbler in Classroom 137	1.2	ppb	0.2	ppb
04500-141-S	Sink in Music Room	0.7	ppb		
04500-141-SWB	Sink with Bubbler in Music Room	0.4	ppb	0.1	ppb
04500-142-SWB	Sink with Bubbler in Classroom 142	0.5	ppb	1.2	ppb
04500-142-S	Sink in Classroom 142	0.5	ppb		
04500-145-S	Sink in Classroom 145	0.6	ppb		
04500-145-SWB	Sink with Bubbler in Classroom 145	0.3	ppb	0.1	ppb
04500-146-S	Sink in Classroom 146	0.3	ppb		
04500-146-SWB	Sink with Bubbler in Classroom 146	0.6	ppb	0.2	ppb
04500-150H-DF	Hallway Drinking Fountain near Classroom 148	0.4	ppb	0.3	ppb
04500-147-SWB	Sink with Bubbler in Classroom 147	0.4	ppb	0.1	ppb
04500-147-S	Sink in Classroom 147	0.3	ppb		
04500-148-SWB	Sink with Bubbler in Classroom 148	0.7	ppb	0.1	ppb
04500-148-S	Sink in Classroom 148	0.4	ppb		
04500-155H-DF	Hallway Drinking Fountain near Classroom 155	0.1	ppb	<0.1*	ppb
04500-155H-S	Hallway Sink near Classroom 155	0.7	ppb		
04500-182H-S	Hallway Sink near Classroom 178	0.4	ppb		
04500-182H-DF	Hallway Drinking Fountain near Classroom 178	0.1	ppb	0.2	ppb
04500-185-S	Sink in Kindergarten Classroom 185	1.2	ppb		
04500-186-S	Sink in Kindergarten Classroom 186	0.4	ppb		
04500-188-S	Art Room Sink	1.1	ppb		
04500-186-SWB	Sink with Bubbler in Kindergarten Classroom 186	0.3	ppb	0.2	ppb
04500-102H-DF	Hallway Drinking Fountain near Gym	<0.1*	ppb	<0.1*	ppb
04500-121-S	Sink in Clinic	0.4	ppb	0.5	ppb
04500-R1-116-DF	Drinking Fountain in Temp R1-116	8.0	ppb	3.9	ppb
04500-R1-186-DF	Drinking Fountain in Temp R1-186	8.0	ppb	7.4	ppb

* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.