

Bradford Intermediate School - Sampled 9/14/16				Resampled** 9/14/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Unit
05200-223-S1	Art Room Sink	1.7	ppb		
05200-223-S2	Art Room Sink	2.6	ppb		
05200-203H-DFL	Hallway Drinking Fountain across from Gym/Left	0.1	ppb		
05200-203H-DFR	Hallway Drinking Fountain across from Gym/Right	<0.1 *	ppb		
05200-211-S1	Food Service Sink-Rinse	6.4	ppb		
05200-211-S2	Food Service Sink-Wash	2.0	ppb		
05200-211-S3	Food Service Sink-Sprayer	2.7	ppb		
05200-211-S4	Food Service Sink-Hand Sink	0.7	ppb		
05200-210-S1	Food Service Sink-Food Warmer	5.3	ppb		
05200-210-S2	Food Service Sink-Food Warmer	5.1	ppb		
05200-210-S3	Food Service Sink-Hand Sink	0.5	ppb		
05200-210-S4	Food Service Sink-Food Prep	4.5	ppb		
05200-201-SWB	Sink with Bubbler in Music Room	1.1	ppb		
05200-201-S	Sink in Music Room	14.7	ppb		
05200-181H-DF	Hallway Drinking Fountain near Library	0.2	ppb		
05200-018-SWB	Sink with Bubbler in Classroom 018	0.4	ppb		
05200-018-S	Sink in Classroom 018	0.5	ppb		
05200-017-S	Sink in Classroom 2 (Room 017 per Facilities Floor Plan)	9.9	ppb		
05200-017-SWB	Sink with Bubbler in Classroom 2 (Room 017 per Facilities Floor Plan)	1.7	ppb		
05200-016-S	Sink in Classroom 3 (Room 016 per Facilities Floor Plan)	26.1	ppb	2.9	ppb
05200-016-SWB	Sink with Bubbler in Classroom 3 (Room 016 per Facilities Floor Plan)	2.9	ppb		
05200-015-SWB	Sink with Bubbler in Classroom 4 (Room 015 per Facilities Floor Plan)	0.2	ppb		
05200-015-S	Sink in Classroom 4 (Room 015 per Facilities Floor Plan)	2.6	ppb		
05200-014-SWB	Sink with Bubbler in Classroom 5 (Room 014 per Facilities Floor Plan)	5.2	ppb		
05200-014-S	Sink in Classroom 5 (Room 014 per Facilities Floor Plan)	12.9	ppb		
05200-013-S	Sink Classroom 6 (Room 013 per Facilities Floor Plan)	9.5	ppb		
05200-013-SWB	Sink with Bubbler in Classroom 6 (Room 013 per Facilities Floor Plan)	0.5	ppb		
05200-012-SWB	Sink with Bubbler in Classroom 7 (Room 012 per Facilities Floor Plan)	0.5	ppb		
05200-012-S	Sink in Classroom 7 (Room 012 per Facilities Floor Plan)	12.8	ppb		
05200-011-S	Sink in Classroom 8 (Room 011 per Facilities Floor Plan)	8.3	ppb		
05200-011-SWB	Sink with Bubbler in Classroom 8 (Room 011 per Facilities Floor Plan)	0.3	ppb		
05200-010-S	Sink in Classroom 9 (Room 010 per Facilities Floor Plan)	7.0	ppb		
05200-010-SWB	Sink with Bubbler in Classroom 9 (Room 010 per Facilities Floor Plan)	0.4	ppb		
05200-009-SWB	Sink with Bubbler in Classroom 10 (Room 009 per Facilities Floor Plan)	0.9	ppb		
05200-009-S	Sink in Classroom 10 (Room 009 per Facilities Floor Plan)	4.4	ppb		
05200-008-SWB	Sink with Bubbler in Classroom 11 (Room 008 per Facilities Floor Plan)	0.6	ppb		
05200-008-S	Sink in Classroom 11 (Room 008 per Facilities Floor Plan)	6.0	ppb		
05200-007-S	Sink in Classroom 12 (Room 007 per Facilities Floor Plan)	9.8	ppb		
05200-007-SWB	Sink with Bubbler in Classroom 12 (Room 007 per Facilities Floor Plan)	0.7	ppb		
05200-006-SWB	Sink with Bubbler in Classroom 13 (Room 006 per Facilities Floor Plan)	0.4	ppb		
05200-006-S	Sink in Classroom 13 (Room 006 per Facilities Floor Plan)	5.0	ppb		
05200-005-S	Sink in Classroom 14 (Room 005 per Facilities Floor Plan)	10.0	ppb		
05200-005-SWB	Sink with Bubbler in Classroom 14 (Room 005 per Facilities Floor Plan)	0.2	ppb		
05200-004-S	Sink in Classroom 15 (Room 004 per Facilities Floor Plan)	12.4	ppb		
05200-004-SWB	Sink with Bubbler in Classroom 15 (Room 004 per Facilities Floor Plan)	1.4	ppb		
05200-001-SWB	Sink with Bubbler in Classroom 16 (Room 001 per Facilities Floor Plan)	5.1	ppb		
05200-001-S	Sink in Classroom 16 (Room 001 per Facilities Floor Plan)	24.2	ppb	2.3	ppb
05200-002-SWB	Sink with Bubbler in Classroom 17 (Room 002 per Facilities Floor Plan)	3.3	ppb		
05200-002-S	Sink in Classroom 17 (Room 002 per Facilities Floor Plan)	9.6	ppb		
05200-003-S	Sink in Classroom 18 (Room 003 per Facilities Floor Plan)	5.5	ppb		
05200-003-SWB	Sink with Bubbler in Classroom 18 (Room 003 per Facilities Floor Plan)	0.9	ppb		
05200-186-S	Sink in Library Workroom	3.1	ppb		
05200-114-S	Sink in Teacher's Lounge	0.9	ppb		
05200-106-S	Sink in Clinic	7.3	ppb		
05200-106-SWB	Sink with Bubbler in Clinic	4.4	ppb		
05200-105-S	Sink in Workroom 105	1.8	ppb		

* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.

** Resampling results after elevated fixtures were repaired, or removed and replaced.