

Columbine High School - Sampled 9/23/16				Resampled** 12/1/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Unit
73500-UH1H-WBFS	Water Bottle Filling Station near Classroom MA11	<0.1 *	ppb		
73500-UH1H-DF	Drinking Fountain near Classroom MA11	<0.1 *	ppb		
73500-SCI-7-S1	Sink in Laboratory SCI-7	4.8	ppb		
73500-SCI-7-S3	Sink in Laboratory SCI-7	1.1	ppb		
73500-SCI-7-S4	Sink in Laboratory SCI-7	2.5	ppb		
73500-SCI-7-S5	Sink in Laboratory SCI-7	1.7	ppb		
73500-SCI-7-S6	Sink in Laboratory SCI-7	1.9	ppb		
73500-UA-5-S	Sink in Storage Room UA-5	1.3	ppb		
73500-SCI-6-S1	Sink in Laboratory SCI-6	6.6	ppb		
73500-SCI-6-S2	Sink in Laboratory SCI-6	1.9	ppb		
73500-SCI-6-S3	Sink in Laboratory SCI-6	11.8	ppb		
73500-SCI-6-S5	Sink in Laboratory SCI-6	3.6	ppb		
73500-SCI-6-S6	Sink in Laboratory SCI-6	3.9	ppb		
73500-SCI-5-S2	Sink in Laboratory SCI-5	2.3	ppb		
73500-SCI-5-S3	Sink in Laboratory SCI-5	1.5	ppb		
73500-SCI-5-S4	Sink in Laboratory SCI-5	8.7	ppb		
73500-SCI-4-S1	Sink in Laboratory SCI-4	1.2	ppb		
73500-SCI-4-S2	Sink in Laboratory SCI-4	2.4	ppb		
73500-SCI-4-S3	Sink in Laboratory SCI-4	2.8	ppb		
73500-SCI-4-S4	Sink in Laboratory SCI-4	1.7	ppb		
73500-SCI-4-S5	Sink in Laboratory SCI-4	2.0	ppb		
73500-SCI-4-S6	Sink in Laboratory SCI-4	3.1	ppb		
73500-UA-9-S	Sink in Work Room UA-9	2.3	ppb		
73500-SCI-3-S1	Sink in Laboratory SCI-3	0.8	ppb		
73500-SCI-3-S2	Sink in Laboratory SCI-3	1.2	ppb		
73500-SCI-3-S3	Sink in Laboratory SCI-3	1.8	ppb		
73500-SCI-3-S4	Sink in Laboratory SCI-3	2.6	ppb		
73500-SCI-3-S5	Sink in Laboratory SCI-3	1.4	ppb		
73500-SCI-3-S6	Sink in Laboratory SCI-3	1.6	ppb		
73500-SCI-2-S1	Sink in Laboratory SCI-2	4.1	ppb		
73500-SCI-2-S2	Sink in Laboratory SCI-2	1.5	ppb		
73500-SCI-2-S3	Sink in Laboratory SCI-2	3.9	ppb		
73500-SCI-2-S4	Sink in Laboratory SCI-2	1.1	ppb		
73500-SCI-2-S5	Sink in Laboratory SCI-2	1.1	ppb		
73500-SCI-2-S6	Sink in Laboratory SCI-2	1.2	ppb		
73500-SCI-8-S1	Sink in Laboratory SCI-8	3.0	ppb		
73500-SCI-8-S2	Sink in Laboratory SCI-8	1.1	ppb		
73500-SCI-8-S3	Sink in Laboratory SCI-8	1.5	ppb		
73500-SCI-8-S4	Sink in Laboratory SCI-8	1.0	ppb		
73500-SCI-8-S5	Sink in Laboratory SCI-8	1.3	ppb		
73500-SCI-8-S6	Sink in Laboratory SCI-8	0.9	ppb		
73500-UA-21-S1	Sink in Science Prep Room UA-21	3.5	ppb		
73500-UA-21-S2	Sink in Science Prep Room UA-21	1.6	ppb		
73500-SCI-10-S1	Sink in Laboratory SCI-10	1.1	ppb		
73500-SCI-10-S2	Sink in Laboratory SCI-10	3.0	ppb		
73500-SCI-10-S3	Sink in Laboratory SCI-10	10.4	ppb		
73500-SCI-10-S4	Sink in Laboratory SCI-10	2.3	ppb		
73500-SCI-10-S5	Sink in Laboratory SCI-10	1.1	ppb		
73500-SCI-10-S6	Sink in Laboratory SCI-10	0.7	ppb		
73500-SCI-10-S7	Sink in Laboratory SCI-10	8.6	ppb		
73500-SCI-1-S1	Sink in Laboratory SCI-1	2.7	ppb		
73500-SCI-1-S2	Sink in Laboratory SCI-1	2.3	ppb		
73500-SCI-1-S3	Sink in Laboratory SCI-1	92.0	ppb	4.2	ppb
73500-SCI-1-S4	Sink in Laboratory SCI-1	0.6	ppb		
73500-SCI-1-S5	Sink in Laboratory SCI-1	48.5	ppb	0.6	ppb
73500-SCI-1-S6	Sink in Laboratory SCI-1	1.0	ppb		

73500-UA-24-S	Sink in Science Storage UA-24	56.0	ppb	7.9	ppb
73500-SCI-9-S1	Sink in Laboratory SCI-9	3.6	ppb		
73500-SCI-9-S2	Sink in Laboratory SCI-9	1.7	ppb		
73500-SCI-9-S3	Sink in Laboratory SCI-9	3.9	ppb		
73500-SCI-9-S4	Sink in Laboratory SCI-9	1.7	ppb		
73500-SCI-9-S5	Sink in Laboratory SCI-9	3.5	ppb		
73500-SCI-9-S6	Sink in Laboratory SCI-9	3.3	ppb		
73500-SCI-9-S7	Sink in Laboratory SCI-9	15.0	ppb		
73500-UA1H-DF	Hallway Drinking Fountain outside of SCI-9	1.0	ppb		
73500-LB2-S1	Food Service Sink-Hand Sink	30.4	ppb	0.7	ppb
73500-LB2-S2	Food Service Sink-Food Prep	1.1	ppb		
73500-LB2-S3	Food Service Sink-Wash/Rinse	0.9	ppb		
73500-LB2-S4	Food Service Sink-Rinse/Sanitize	1.1	ppb		
73500-LB2-S5	Food Service Sink-Sprayer	2.8	ppb		
73500-LB2-S6	Food Service Sink-Hand Sink	1.8	ppb		
73500-LB2-S7	Food Service Sink-Sprayer	33.6	ppb	7.9	ppb
73500-LB2-S8	Food Service Sink-Hand Sink	12.4	ppb		
73500-LB2-S9	Food Service Sink-Filler Bucket	10.1	ppb		
73500-LB3-S	Sink in Teacher's Lounge	5.9	ppb		
73500-LA2H-WBFS	Hallway Water Bottle Filling Station outside of Cafeteria	<0.1 *	ppb		
73500-LA2H-DF	Drinking Fountain outside of Cafeteria	<0.1 *	ppb		
73500-UE9H-DF	Hallway Drinking Fountain in the Lobby	<0.1 *	ppb		
73500-20H-WBFS	Hallway Water Bottle Filling Station outside of Girl's Locker Room	<0.1 *	ppb		
73500-20H-DF	Hallway Drinking Fountain outside of Girl's Locker Room	<0.1 *	ppb		
73500-53-S	Sink in Training Room	0.1	ppb		
73500-UE15-DF	Drinking Fountain in Weight Room	<0.1 *	ppb		
73500-UC4-DF	Drinking Fountain in Small Gym	<0.1 *	ppb		
73500-UC7-DF	Drinking Fountain in Girl's Locker Room	1.7	ppb		
73500-UC15-DF	Drinking Fountain in Men's Locker Room	1.0	ppb		
73500-UC18-DF	Drinking Fountain in Boy's PE Locker Room	4.2	ppb		
73500-UC31-DF	Drinking Fountain in Girl's Athletic Locker Room	16.1	ppb		Repairs Pending
73500-UB23AXH-DF	Hallway Drinking Fountain outside of Activity Room UB-21	0.3	ppb		
73500-113-DFL	Drinking Fountain in Library Lobby/Left	0.1	ppb		
73500-113-DFR	Drinking Fountain in Library Lobby/Right	0.1	ppb		
73500-109-S	Sink in Processing Room 109	0.5	ppb		
73500-SCI-11-S1	Sink in Laboratory SCI-11	1.6	ppb		
73500-SCI-11-S2	Sink in Laboratory SCI-11	1.7	ppb		
73500-CL1-DF	Drinking Fountain in Computer Lab 1	1.1	ppb		
73500-SCI-12-S1	Sink in Laboratory SCI-12	2.4	ppb		
73500-UF26-S	Sink in Storage Room UF-26	3.3	ppb		
73500-LM2-S	Sink in Consumer Science Room LM-2	0.6	ppb		
73500-LM2-SWB	Sink with Bubbler in Consumer Science Room LM-2	2.7	ppb		
73500-UD23-S1	Sink in Kitchen Classroom UD-23	0.5	ppb		
73500-UD23-S2	Sink in Kitchen Classroom UD-23	0.6	ppb		
73500-UD23-S3	Sink in Kitchen Classroom UD-23	1.1	ppb		
73500-UD23-S4	Sink in Kitchen Classroom UD-23	0.3	ppb		
73500-UD23-S5	Sink in Kitchen Classroom UD-23	0.8	ppb		
73500-UD23-S6	Sink in Kitchen Classroom UD-23	0.3	ppb		
73500-UD23-S7	Sink in Kitchen Classroom UD-23	0.4	ppb		
73500-UD1H-DF	Hallway Drinking Fountain across from Office UD1H	0.1	ppb		
73500-UD36-S	Sink in Instrument/Band Office	0.3	ppb		
73500-UD36-DF	Drinking Fountain in Instrument/Band Office	1.5	ppb		
73500-UD15-S1	Sink in Art Room UD-15	2.2	ppb		
73500-UD15-S2	Sink in Art Room UD-15	5.1	ppb		
73500-UD16X-S2	Sink in Storage Room UD-16X	45.1	ppb	5.4	ppb
73500-UD19-S	Sink in Art Room UD-19	3.6	ppb		
73500-UD21-S1	Sink in Art Room UD-21	0.3	ppb		
73500-UD21-S2	Sink in Art Room UD-21	0.6	ppb		

73500-UE8-S1	Sink in Art Room UE-8	5.1	ppb	
73500-UE8-S2	Sink in Art Room UE-8	3.0	ppb	
73500-UE27-S	Sink in Planning Room UE-27	1.1	ppb	
73500-UE36-S	Sink in Clinic	2.9	ppb	
73500-UE27-WC	Water Cooler in Planning Room UE-27	<0.1 *	ppb	
73500-BUS6-5	Sink in Classroom BUS 6	0.2	ppb	
73500-SE1-S	Sink in Resource Room SE-1	2.2	ppb	
73500-YC53-IM	Ice Machine in Training Room UC-53	0.2	ppb	
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.				
** Resampling results after elevated fixtures were repaired, or removed and replaced.				