

Columbine Hills Elementary School - Sampled 6/22/16			
CustomerSampleNumber	Description	Lead Result	Units
09500-156-SWB	Sink with Bubblers in Classroom 156	0.2	ppb
09500-155-SWB	Sink with Bubblers in Classroom 155	0.4	ppb
09500-154-SWB	Sink with Bubblers in Classroom 154	1.0	ppb
09500-153-SWB	Sink with Bubblers in Kindergarten Classroom 153	0.1	ppb
09500-152-SWB	Sink with Bubblers in Kindergarten Classroom 152	0.9	ppb
09500-150-SWB	Sink with Bubblers in Classroom 150	1.9	ppb
09500-158H-DFL	Hallway Drinking Fountain near Kindergarten Classroom 153/Left	4.2	ppb
09500-158H-DFR	Hallway Drinking Fountain near Kindergarten Classroom 153/Right	2.7	ppb
09500-143-SWB	Sink with Bubblers in Classroom 143	1.2	ppb
09500-142-SWB	Sink with Bubblers in Classroom 142	0.2	ppb
09500-138-S	Sink in Clinic	0.6	ppb
09500-140-S	Sink in Office Workroom	0.3	ppb
09500-100H-DF	Hallway Drinking Fountain near Principal's Office	0.2	ppb
09500-129-S	Sink in Teacher's Lounge	0.4	ppb
09500-128-S	Art Room Sink	1.0	ppb
09500-128-SWB	Sink with Bubblers in Art Room	0.6	ppb
09500-C101-SWB	Sink with Bubblers in Classroom C101	1.8	ppb
09500-113XH-DF	Hallway Drinking Fountain near Classroom C103	6.9	ppb
09500-C103-SWB	Sink with Bubblers in Classroom C103	1.9	ppb
09500-C104-SWB	Sink with Bubblers in Classroom 104	3.2	ppb
09500-C105-SWB	Sink with Bubblers in Classroom 105	5.6	ppb
09500-C106F-S	Sink in Library Workroom	1.3	ppb
09500-C111-SWB	Sink with Bubblers in Room C111	2.7	ppb
09500-101XH-DF	Hallway Drinking Fountain near Classroom C113	3.6	ppb
09500-C113-SWB	Sink with Bubblers in Classroom C113	3.8	ppb
09500-C112-SWB	Sink with Bubblers in Classroom C112	2.2	ppb
09500-C100-SWB	Sink with Bubblers in Classroom C100	0.9	ppb
09500-B109BH-DF	Hallway Drinking Fountain near Classroom B103	0.2	ppb
09500-B103-SWB	Sink with Bubblers in Classroom B103	4.7	ppb
09500-B107-SWB	Sink with Bubblers in Classroom B107	1.8	ppb
09500-B108-SWB	Sink with Bubblers in Classroom B108	1.1	ppb
09500-B105-SWB	Sink with Bubblers in Classroom B105	0.8	ppb
09500-119H-DFL1	Hallway Drinking Fountain near Gym/Left	9.8	ppb
09500-119H-DFL2	Hallway Drinking Fountain near Gym/Left	10.7	ppb
09500-119H-DFR1	Hallway Drinking Fountain near Gym/Right	4.3	ppb
09500-119H-DFR2	Hallway Drinking Fountain near Gym/Right	2.3	ppb
09500-102-S1	Food Service Sink-Hand Sink	5.0	ppb
09500-102-S2	Food Service Sink-Food Prep	5.1	ppb
09500-102-S3	Food Service Sink-Wash/Rinse/Sanitize	8.9	ppb
09500-102-S4	Food Service Sink-Wash/Rinse/Sanitize	4.6	ppb