

Connections Learning Center - Sampled 10/7/16			
CustomerSampleNumber	Description	Lead Result	Unit
85001-302-DFL	Drinking Fountain in Cafeteria/Left	0.4	ppb
85001-302-DFC	Drinking Fountain in Cafeteria/Center	0.3	ppb
85001-302-DFR	Drinking Fountain in Cafeteria/Right	0.4	ppb
85001-103H-DF	Hallway Drinking Fountain across from Classroom 106 and 102	0.4	ppb
85001-101-S	Sink in Classroom 101	0.3	ppb
85001-113AH-DFL	Hallway Drinking Fountain across from Classroom 110 and 114/Left	0.3	ppb
85001-113AH-DFR	Hallway Drinking Fountain across from Classroom 110 and 114/Right	0.3	ppb
85001-111A-S	Sink in Science Prep Room 111A	0.5	ppb
85001-109-S1	Sink in Laboratory 109	0.2	ppb
85001-109-S2	Sink in Laboratory 109	0.3	ppb
85001-113-S1	Sink in Laboratory 113	0.3	ppb
85001-219-WC	Water Cooler in Teacher's Lounge	0.2	ppb
85001-219-S	Sink in Teacher's Lounge	1.0	ppb
85001-211-S	Sink in Clinic	0.3	ppb