

Creighton Middle School - Sampled 10/21/16			
CustomerSampleNumber	Description	Lead Result	Unit
64300-1107-S	Sink in Clinic	0.3	ppb
64300-1115-S	Sink in Workroom 1115	0.5	ppb
64300-1115-WD	Water Dispenser in Refrigerator in Workroom 1115	< 0.1 *	ppb
64300-163-S	Sink in Science Prep Room 163	1.6	ppb
64300-110-S1	Sink in Consumer Science Kitchen Room 110	0.3	ppb
64300-110-S2	Sink in Consumer Science Kitchen Room 110	0.2	ppb
64300-110-S3	Sink in Consumer Science Kitchen Room 110	0.1	ppb
64300-110-S4	Sink in Consumer Science Kitchen Room 110	0.3	ppb
64300-110-S5	Sink in Consumer Science Kitchen Room 110	0.4	ppb
64300-110-S6	Sink in Consumer Science Kitchen Room 110	0.3	ppb
64300-110-S7	Sink in Consumer Science Kitchen Room 110	0.2	ppb
64300-153-IM	Ice Machine in Refrigerator in Storage Room near Consumer Science Kitchen Room 110	1.0	ppb
64300-153-WD	Water Dispenser in Refrigerator in Storage Room near Consumer Science Kitchen Room 110	0.5	ppb
64300-101XH-DFL	Hallway Drinking Fountain near Restroom by Classroom 108/Left	< 0.1 *	ppb
64300-101XH-DFR	Hallway Drinking Fountain near Restroom by Classroom 108/Right	< 0.1 *	ppb
64300-107AX-S	Sink in Science Prep Room 107AX (between Classrooms 104 and 105)	0.3	ppb
64300-125-S	Sink in Prep/Workroom 125	0.2	ppb
64300-177H-DFL	Hallway Drinking Fountain near Restroom by Classroom 101/Left	< 0.1 *	ppb
64300-177H-DFR	Hallway Drinking Fountain near Restroom by Classroom 101/Right	0.1	ppb
64300-175-S	Sink in Library Workroom	0.2	ppb
64300-183-DFL	Drinking Fountain in Gym/Left	< 0.1 *	ppb
64300-183-DFR	Drinking Fountain in Gym/Right	< 0.1 *	ppb
64300-1145-DF	Drinking Fountain in Cafeteria	0.2	ppb
64300-1146-S1	Food Service Sink - Hand Sink	0.3	ppb
64300-1146-S3	Food Service Sink - Faucet over Disposal in Food Prep Area	5.0	ppb
64300-1146-S4	Food Service Sink - Food Prep Sprayer	3.4	ppb
64300-1146-S5	Food Service Sink - Food Prep Sink	0.4	ppb
64300-1146-S7	Food Service Sink - Hand Sink	0.5	ppb
64300-1147-S1	Food Service Sink - Wash/Rinse Sink	3.6	ppb
64300-1147-S2	Food Service Sink - Rinse/Sanitize Sink	1.5	ppb
64300-1147-S3	Food Service Sink - Sprayer in Dishwashing Area	5.9	ppb
64300-1144H-DFL	Hallway Drinking Fountain near Restrooms outside of Cafeteria/Left	0.2	ppb
64300-1144H-DFR	Hallway Drinking Fountain near Restrooms outside of Cafeteria/Right	< 0.1 *	ppb
64300-1167-DF	Drinking Fountain in Fabrication Shop Room 1167	< 0.1 *	ppb
64300-1142-S	Sink in Vocal Classroom 1142	0.2	ppb
64300-1142-SWB	Sink with Bubbler in Vocal Classroom 1142	< 0.1 *	ppb
64300-1136-S	Sink in Instrument/Band Classroom 1136	0.3	ppb
64300-1136-SWB	Sink with Bubbler in Instrument/Band Classroom 1136	< 0.1 *	ppb
64300-1132A-S	Sink in Concessions Area Room 1132A	0.4	ppb
64300-222H-DFL	Hallway Drinking Fountain near Restroom by Classroom 201/Left	0.2	ppb
64300-222H-DFR	Hallway Drinking Fountain near Restroom by Classroom 201/Right	< 0.1 *	ppb
64300-215XH-DFL	Hallway Drinking Fountain near Restroom by Classroom 208/Left	0.1	ppb
64300-215XH-DFR	Hallway Drinking Fountain near Restroom by Classroom 208/Right	0.5	ppb
64300-223-S	Sink in Prep/Workroom 223	2.0	ppb
64300-204-S1	Sink in Science Classroom 204	1.6	ppb
64300-204-S2	Sink in Science Classroom 204	0.3	ppb
64300-204-S3	Sink in Science Classroom 204	2.7	ppb
64300-204-S4	Sink in Science Classroom 204	3.9	ppb
64300-207X-S	Sink in Science Prep Room 207X (between Rooms 204 and 205)	0.4	ppb
64300-245-S	Sink in Art Storage Room 245	0.3	ppb
64300-253-S	Sink in Science Prep Room 253	0.4	ppb

* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.