

Deane Elementary - Sampled 6/14/16			
CustomerSampleNumber	Description	Lead Result	Unit
42000-056-S1	Food Service Sink	3.3	ppb
42000-014H-DFL	Hallway Drinking Fountain/Left-Outside Gym	15.7	ppb
42000-014H-DFR	Hallway Drinking Fountain/Right-Outside Gym	6.6	ppb
42000-059H-DF	Hallway Drinking Fountain Near Room 18	11.0	ppb
42000-019-SWB	Sink with Bubbler in Room 19	2.0	ppb
42000-021-SWB	Sink with Bubbler in Room 21	0.9	ppb
42000-022-SWB	Sink with Bubbler in Room 22	2.3	ppb
42000-020-SWB	Sink with Bubbler in Room 20	0.8	ppb
42000-018-SWB	Sink with Bubbler in Room 18	2.6	ppb
42000-029-SWB	Sink with Bubbler in Room 29	1.9	ppb
42000-30H-DF	Hallway Drinking Fountain Near Room 30	0.3	ppb
42000-032-SWB	Sink with Bubbler in Room 32	0.2	ppb
42000-028-SWB	Sink with Bubbler in Room 28	2.6	ppb
42000-030-SWB	Sink with Bubbler in Room 30	2.1	ppb
42000-026-S1	Art Room Sink	0.5	ppb
42000-026-S2	Art Room Sink	0.6	ppb
42000-025-SWB	Sink with Bubbler in Room 25	0.5	ppb
42000-074-S	Sink in Teacher's Lounge	2.0	ppb
42000-004-SWB	Sink with Bubbler in Room 4	3.9	ppb
42000-007H-DFR	Hallway Drinking Fountain/Right-Near Room 4	25.2	ppb
42000-007H-DFL	Hallway Drinking Fountain/Left-Near Room 4	21.8	ppb
42000-006-SWB	Sink with Bubbler in Room 6	6.1	ppb
42000-008-SWB	Sink with Bubbler in Room 8	6.7	ppb
42000-010-SWB	Sink with Bubbler in Kindergarten Room 10	10.1	ppb
42000-012-SWB	Sink with Bubbler in Kindergarten Room 12	6.2	ppb
42000-015-SWB	Sink with Bubbler in Kindergarten Room 15	5.1	ppb
42000-011-SWB	Sink with Bubbler in Room 11	7.2	ppb
42000-009-SWB	Sink with Bubbler in Room 9	4.6	ppb
42000-089-S	Sink in Office Workroom	1.1	ppb
42000-086-S	Sink in Clinic	0.7	ppb
42000-088-S	Sink in Clinic Restroom	8.2	ppb
42000-R1-179-DF	Drinking Fountain in Temp R1-179	7.8	ppb
42000-RE-014-DF	Drinking Fountain in Temp RE-014	1.2	ppb
42000-RE-021-DF	Drinking Fountain in Temp RE-021	0.6	ppb