

Dutch Creek Elementary School - Sampled 6/22/16			
CustomerSampleNumber	Description	Lead Result	Units
10900-001D-S	Sink in Library Storage Room	22.6	ppb
10900-001C-S	Sink in Library Workroom	7.5	ppb
10900-017DH-S	Hallway Sink across from Main Office	0.6	ppb
10900-017DH-SWB	Hallway Sink with Bubbler across from Main Office	1.6	ppb
10900-006BH-S	Hallway Sink near Classroom 006	10.8	ppb
10900-006BH-SWB	Hallway Sink with Bubbler near Classroom 006	5.0	ppb
10900-009BH-S	Hallway Sink near Classroom 008	5.4	ppb
10900-009BH-SWB	Hallway Sink with Bubbler near Classroom 008	2.0	ppb
10900-047-S1	Food Service Sink-Prep Sink	9.2	ppb
10900-047-S2	Food Service Sink-Sanitize	9.0	ppb
10900-047-S3	Food Service Sink-Rinse	9.3	ppb
10900-047-S4	Food Service Sink-Hand Sink	7.9	ppb
10900-110-DFL	Hallway Drinking Fountain near Music Room/Left	<0.1 *	ppb
10900-110-DFR	Hallway Drinking Fountain near Music Room/Right	<0.1 *	ppb
10900-030-S1	Art Room Sink	2.2	ppb
10900-030-S2	Art Room Sink	4.4	ppb
10900-031-S	Sink in Classroom 031	0.3	ppb
10900-031-SWB	Sink with Bubbler in Classroom 031	9.4	ppb
10900-041-S	Sink in Classroom 041	9.3	ppb
10900-041-SWB	Sink with Bubbler in Classroom 041	<0.1 *	ppb
10900-032-S	Sink in Classroom 032	14.9	ppb
10900-032-SWB	Sink with Bubbler in Classroom 032	0.2	ppb
10900-119H-DFL	Hallway Drinking Fountain across from Classroom 033/Left	0.2	ppb
10900-119H-DFR	Hallway Drinking Fountain across from Classroom 033/Right	<0.1 *	ppb
10900-033-SWB	Sink with Bubbler in Classroom 033	0.2	ppb
10900-033-S	Sink in Classroom 033	5.7	ppb
10900-034-SWB	Sink with Bubbler in Classroom 034	0.2	ppb
10900-034-S	Sink in Classroom 034	20.1	ppb
10900-035-SWB	Sink with Bubbler in Classroom 035	0.1	ppb
10900-039-SWB	Sink with Bubbler in Classroom 039	0.4	ppb
10900-039-S	Sink in Classroom 039	14.2	ppb
10900-040-SWB	Sink with Bubbler in Classroom 040	0.3	ppb
10900-040-S	Sink in Classroom 040	14.0	ppb
10900-043-S2	Sink in Kindergarten Classroom 043	3.4	ppb
10900-036-SWB	Sink with Bubbler in Classroom 036	<0.1 *	ppb
10900-036-S	Sink in Classroom 036	4.6	ppb
10900-037-S	Sink in Classroom 037	4.7	ppb
10900-037-SWB	Sink with Bubbler in Classroom 037	<0.1 *	ppb
10900-038-SWB	Sink with Bubbler in Classroom 038	<0.1 *	ppb
10900-038-S	Sink in Classroom 038	2.8	ppb
10900-043-S1	Sink in Kindergarten Classroom 043	2.7	ppb
10900-043-SWB2	Sink with Bubbler in Kindergarten Classroom 043	1.9	ppb

10900-043-SWB1	Sink with Bubbler in Kindergarten Classroom 043	2.3	ppb
10900-046A-S1	Sink in Hallway near Teacher's Lounge	3.4	ppb
10900-046A-SWB1	Sink with Bubbler in Hallway near Teacher's Lounge	5.0	ppb
10900-046A-S2	Sink in Hallway near Teacher's Lounge	3.3	ppb
10900-046A-SWB2	Sink with Bubbler in Hallway near Teacher's Lounge	5.7	ppb
10900-548-S	Sink in Teacher's Lounge	4.4	ppb
10900-035-S	Sink in Classroom 035	0.3	ppb
10900-D17H-S	Sink in Clinic	7.1	ppb
10900-D17H-SWB	Sink with Bubbler in Clinic	1.3	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.			