

| Edgewater Elementary School - Sampled 6/3/16 |   |             |       |
|--|---|-------------|-------|
| CustomerSampleNumber                         | Description                                     | Lead Result | Units |
| 11000-203-DFL                                | C-Wing Drinking Fountain/Left                   | 0.3         | ppb   |
| 11000-203-DFR                                | C-Wing Drinking Fountain/Right                  | 0.2         | ppb   |
| 11000-203-S                                  | C-Wing Sink Near Room C-3                       | 2.7         | ppb   |
| 11000-104-DFL                                | B-Wing Drinking Fountain/Left                   | 0.3         | ppb   |
| 11000-104-DFR                                | B-Wing Drinking Fountain/Right                  | 0.2         | ppb   |
| 11000-104-S                                  | B-Wing Sink Near Room B-2                       | 4.6         | ppb   |
| 11000-B-5-S                                  | Art Room Sink                                   | 2.4         | ppb   |
| 11000-B-1-S                                  | Music Room Sink                                 | 2.2         | ppb   |
| 11000-105-DF                                 | Drinking Fountain in B-Wing Hall Near Restrooms | 5.0         | ppb   |
| 11000-119-DF                                 | Drinking Fountain in Basement Near Elevator     | 0.5         | ppb   |
| 11000-A-1-SWB                                | Sink with Bubbler in Room A-1                   | 1.5         | ppb   |
| 11000-A-2-SWB                                | Sink with Bubbler in Room A-2                   | 2.7         | ppb   |
| 11000-A-3-SWB                                | Sink with Bubbler in Room A-3                   | 3.2         | ppb   |
| 11000-A-4-SWB                                | Sink with Bubbler in Room A-4                   | 3.4         | ppb   |
| 11000-A-5-SWB                                | Sink with Bubbler in Kindergarten Room A-5      | 1.0         | ppb   |
| 11000-A-6-SWB                                | Sink with Bubbler in Kindergarten Room A-6      | 0.7         | ppb   |
| 11000-A-7-SWB                                | Sink with Bubbler in Kindergarten Room A-7      | 0.5         | ppb   |
| 11000-A-8-SWB                                | Sink with Bubbler in Kindergarten Room A-8      | 2.2         | ppb   |
| 11000-253-S                                  | Sink in Library Workroom                        | 18.0        | ppb   |
| 11000-220-S                                  | Sink in Office Conference Room                  | 0.5         | ppb   |
| 11000-218-S                                  | Sink in Clinic                                  | 0.6         | ppb   |
| 11000-219-S                                  | Sink in Clinic Restroom                         | 0.7         | ppb   |
| 11000-224-S1                                 | Food Service Sink                               | 2.0         | ppb   |
| 11000-224-S2                                 | Food Service Sink                               | 1.8         | ppb   |
| 11000-225-S1                                 | Food Service Sink                               | 1.4         | ppb   |
| 11000-225-S2                                 | Food Service Sink                               | 6.8         | ppb   |
| 11000-225-S3                                 | Food Service Sink                               | 1.3         | ppb   |
| 11000-213A-DF                                | Drinking Fountain on Main Floor by Elevator     | 0.2         | ppb   |
| 11000-C-8-H-DFL                              | C-Wing Drinking Fountain/Left                   | 3.0         | ppb   |
| 11000-208-S                                  | Sink in Teacher's Lounge                        | 0.4         | ppb   |
| 11000-R1-131-DF                              | Drinking Fountain in TEMP R1-131                | 2.7         | ppb   |
| 11000-REC-126-DF                             | Drinking Fountain in TEMP REC-126               | 1.3         | ppb   |
| 11000-R1-100-DF                              | Drinking Fountain in TEMP R1-100                | 4.7         | ppb   |
| 11000-R1-212-DF                              | Drinking Fountain in TEMP R1-212                | 0.7         | ppb   |
| 11000-R1-127-DF                              | Drinking Fountain in TEMP R1-127                | 9.3         | ppb   |
| 11000-RE-012-DF                              | Drinking Fountain in TEMP RE-012                | 1.1         | ppb   |
| 11000-RE-006-DF                              | Drinking Fountain in TEMP RE-006                | 2.3         | ppb   |
| 11000-R1-176-DF                              | Drinking Fountain in TEMP R1-176                | 17.8        | ppb   |
| 11000-R1-054-DF                              | Drinking Fountain in TEMP R1-054                | 4.3         | ppb   |