

Fitzmorris Elementary School - Sampled 7/12/16				Resampled** 8/24/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
14500-101X-DF	Hallway Drinking Fountain near Library	1.2	ppb		
14500-300-BX-S1	Hallway Sink near Cafeteria/Left	1.1	ppb		
14500-300-BX-S2	Hallway Sink near Cafeteria/Right	0.8	ppb		
14500-200-DF	Drinking Fountain in Cafeteria	3.3	ppb		
14500-300-S1	Food Service Sink - Wash/Rinse	9.2	ppb		
14500-300-S2	Food Service Sink - Rinse/Sanitize	29.6	ppb	7.5	ppb
14500-300-S3	Food Service Sink - Food Prep	5.0	ppb		
14500-500H-DF	Hallway Drinking Fountain near Gym (near restrooms)	5.3	ppb		
14500-403-DF	Drinking Fountain near Gym (near PE storage area)	4.3	ppb		
14500-212-S	Sink in Classroom 212	2.3	ppb		
14500-212-SWB	Sink with Bubbler in Classroom 212	2.2	ppb		
14500-213-S	Sink in Classroom 213	2.6	ppb		
14500-213-SWB	Sink with Bubbler in Classroom 213	1.9	ppb		
14500-214-S	Sink in Classroom 214	1.7	ppb		
14500-214-SWB	Sink with Bubbler in Classroom 214	1.4	ppb		
14500-217-S	Sink in Classroom 217	5.1	ppb		
14500-217-SWB	Sink with Bubbler in Classroom 217	5.1	ppb		
14500-220-S	Sink in Classroom 220	9.3	ppb		
14500-220-SWB	Sink with Bubbler in Classroom 220	1.7	ppb		
14500-219-S	Sink in Classroom 219	41.6	ppb	8.0	ppb
14500-219-SWB	Sink with Bubbler in Classroom 219	5.2	ppb		
14500-218-S	Sink in Classroom 218	4.8	ppb		
14500-218-SWB	Sink with Bubbler in Classroom 218	2.8	ppb		
14500-216-S	Sink in Classroom 216	4.4	ppb		
14500-216-SWB	Sink with Bubbler in Classroom 216	2.6	ppb		
14500-215-S	Sink in Classroom 215	4.1	ppb		
14500-215-SWB	Sink with Bubbler in Classroom 215	3.0	ppb		
14500-205A-S	Sink in Teacher's Lounge	2.2	ppb		
14500-103B-S	Sink in Library Workroom	1.3	ppb		
14500-109-S1	Sink in Art Room/Left	2.2	ppb		
14500-109-S2	Sink in Art Room/Right	0.9	ppb		
14500-115-S	Sink in Classroom 115	14.7	ppb		
14500-115-SWB	Sink with Bubbler in Classroom 115	2.1	ppb		
14500-119-S	Sink in Classroom 119	2.8	ppb		
14500-119-SWB	Sink with Bubbler in Classroom 119	1.5	ppb		
14500-120-S	Sink in Classroom 120	4.2	ppb		
14500-120-SWB	Sink with Bubbler in Classroom 120	1.7	ppb		
14500-121-S	Sink in Classroom 121	1.7	ppb		
14500-121-SWB	Sink with Bubbler in Classroom 121	1.5	ppb		
14500-122-S	Sink in Classroom 122	2.6	ppb		
14500-122-SWB	Sink with Bubbler in Classroom 122	0.8	ppb		
14500-118-S	Sink in Classroom 118 (Preschool Office)	4.7	ppb		
14500-118-SWB	Sink with Bubbler in Classroom 118 (Preschool Office)	1.7	ppb		
14500-112-S	Sink in Classroom 112	4.6	ppb		
14500-112-SWB	Sink with Bubbler in Classroom 112	3.0	ppb		
14500-111-S	Sink in Classroom 111	2.7	ppb		
14500-111-SWB	Sink with Bubbler in Classroom 111	0.9	ppb		
14500-110-S	Sink in Classroom 110	2.8	ppb		
14500-110-SWB	Sink with Bubbler in Classroom 110	1.5	ppb		
14500-107-S	Sink in Classroom 107	4.4	ppb		
14500-107-SWB	Sink with Bubbler in Classroom 107	2.3	ppb		
14500-106-S	Sink in Classroom 106	8.3	ppb		
14500-106-SWB	Sink with Bubbler in Classroom 106	4.4	ppb		
14500-105-S	Sink in Classroom 105	6.4	ppb		
14500-105-SWB	Sink with Bubbler in Classroom 105	1.1	ppb		
14500-104-S	Sink in Classroom 104	2.4	ppb		
14500-104-SWB	Sink with Bubbler in Classroom 104	0.8	ppb		
14500-102A-S	Sink in Clinic Restroom	1.0	ppb		
14500-102-S	Sink in Clinic	2.3	ppb		

\*\* Resampling results after elevated fixtures were removed and replaced.