

Ken Caryl Middle School - Sampled 8/18/16				Resampled** 12/1/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Unit
64100-012-S	Sink in Conference Room 012 next to Principal's Office	0.5	ppb		
64100-014-S	Sink in Clinic Restroom	1.2	ppb		
64100-036H-DFL	Hallway Drinking Fountain across from Main Office/Left	0.8	ppb		
64100-036H-DFR	Hallway Drinking Fountain across from Main Office/Right	2.6	ppb		
64100-016-S	Sink in Room 016	14.4	ppb		
64100-029H-DFL	Hallway Drinking Fountain near Restrooms by Main Office/Left	1.0	ppb		
64100-029H-DFR	Hallway Drinking Fountain near Restrooms by Main Office/Right	2.9	ppb		
64100-51-S1	Sink in Classroom 51/Left	1.9	ppb		
64100-51-S2	Sink in Classroom 51/Right	15.3	ppb	7.2	ppb
64100-60-S1	Sink in Science Classroom 60	13.2	ppb		
64100-60-S2	Sink in Science Classroom 60	35.6	ppb	5.5	ppb
64100-60-S3	Sink in Science Classroom 60	21.4	ppb	12.5	ppb
64100-60-S4	Sink in Science Classroom 60	12.5	ppb		
64100-60-S5	Sink in Science Classroom 60	10.7	ppb		
64100-60-S6	Sink in Science Classroom 60	6.5	ppb		
64100-60-S7	Sink in Science Classroom 60	25.0	ppb	1.2	ppb
64100-84XH-DF	Hallway Drinking Fountain outside of Science Classroom 60	0.7	ppb		
64100-88-S	Sink in Science Prep Room 88	44.0	ppb	2.5	ppb
64100-63-S1	Sink in Science Classroom 64 (Room 63 per Facilities Floor Plan)	3.1	ppb		
64100-63-S2	Sink in Science Classroom 64 (Room 63 per Facilities Floor Plan)	1.1	ppb		
64100-63-S3	Sink in Science Classroom 64 (Room 63 per Facilities Floor Plan)	4.6	ppb		
64100-63-S4	Sink in Science Classroom 64 (Room 63 per Facilities Floor Plan)	4.7	ppb		
64100-64-S1	Sink in Science Classroom 63 (Room 64 per Facilities Floor Plan)	1.4	ppb		
64100-64-S2	Sink in Science Classroom 63 (Room 64 per Facilities Floor Plan)	1.7	ppb		
64100-64-S3	Sink in Science Classroom 63 (Room 64 per Facilities Floor Plan)	1.7	ppb		
64100-64-S4	Sink in Science Classroom 63 (Room 64 per Facilities Floor Plan)	1.0	ppb		
64100-66-S1	Sink in Science Classroom 66	20.0	ppb	0.7	ppb
64100-66-S2	Sink in Science Classroom 66	3.6	ppb		
64100-66-S3	Sink in Science Classroom 66	7.4	ppb		
64100-66-S4	Sink in Science Classroom 66	1.4	ppb		
64100-67-S1	Sink in Science Classroom 67	1.3	ppb		
64100-67-S2	Sink in Science Classroom 67	1.1	ppb		
64100-67-S3	Sink in Science Classroom 67	1.8	ppb		
64100-67-S4	Sink in Science Classroom 67	25.6	ppb	0.6	ppb
64100-70-S	Sink in Clothing Lab - Room 70	15.3	ppb	2.9	ppb
64100-135-S1	Sink in Food Lab - Room 86 (Room 135 per Facilities Floor Plan)	5.0	ppb		
64100-135-S2	Sink in Food Lab - Room 86 (Room 135 per Facilities Floor Plan)	0.5	ppb		
64100-135-S3	Sink in Food Lab - Room 86 (Room 135 per Facilities Floor Plan)	0.6	ppb		
64100-135-S4	Sink in Food Lab - Room 86 (Room 135 per Facilities Floor Plan)	0.7	ppb		
64100-135-S5	Sink in Food Lab - Room 86 (Room 135 per Facilities Floor Plan)	3.2	ppb		
64100-135-S6	Sink in Food Lab - Room 86 (Room 135 per Facilities Floor Plan)	24.4	ppb	1.0	ppb
64100-135-S7	Sink in Food Lab - Room 86 (Room 135 per Facilities Floor Plan)	1.1	ppb		
64100-C101H-DFL	Hallway Drinking Fountain by Girl's Locker Room/Left	0.3	ppb		
64100-C101H-DFR	Hallway Drinking Fountain by Girl's Locker Room/Right	0.9	ppb		
64100-161H-DFL	Hallway Drinking Fountain by Boy's Locker Room/Left	0.2	ppb		
64100-161H-DFR	Hallway Drinking Fountain by Boy's Locker Room/Right	0.1	ppb		
64100-89-S1	Sink in CCTV Lab - Room 87 (Room 89 per Facilities Floor Plan)	2.8	ppb		
64100-89-S2	Sink in CCTV Lab - Room 87 (Room 89 per Facilities Floor Plan)	2.8	ppb		
64100-89-S3	Sink in CCTV Lab - Room 87 (Room 89 per Facilities Floor Plan)	1.5	ppb		
64100-100-S	Sink in Teacher's Lounge	0.2	ppb		

64100-100H-DFL	Hallway Drinking Fountain outside of Teacher's Lounge/Left	<0.1 *	ppb	
64100-100H-DFR	Hallway Drinking Fountain outside of Teacher's Lounge/Right	0.2	ppb	
64100-106-S1	Food Service Sink-Hand Sink	4.9	ppb	
64100-106-S2	Food Service Sink-Food Prep	4.1	ppb	
64100-106-S3	Food Service Sink-Sanitize	7.1	ppb	
64100-106-S4	Food Service Sink-Sanitize	2.5	ppb	
64100-106-S5	Food Service Sink-Sprayer	12.1	ppb	
64100-080-S1	Sink in Art Room 080 (the row of four sinks/left)	24.6	ppb	6.4 ppb
64100-080-S2	Sink in Art Room 080 (the row of four sinks/2nd)	9.2	ppb	
64100-080-S3	Sink in Art Room 080 (the row of four sinks/3rd)	8.7	ppb	
64100-080-S4	Sink in Art Room 080 (the row of four sinks/right)	9.3	ppb	
64100-080-S5	Sink in Art Room 080 (the sink by itself)	53.5	ppb	12.1 ppb
64100-78-S1	Sink in Art Room 78	5.6	ppb	
64100-78-S2	Sink in Art Room 78	6.1	ppb	
64100-78-S3	Sink in Art Room 78	5.5	ppb	
64100-78-S4	Sink in Art Room 78	8.3	ppb	
64100-061-S	Sink in Library Work Room	3.2	ppb	
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.				
** Resampling results after elevated fixtures were repaired, or removed and replaced.				