

Kullerstrand Elementary School - Sampled 7/20/16				Resampled** 11/9/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
22300-120-S	Sink in Clinic	0.8	ppb		
22300-003-S	Sink in Kindergarten Classroom 003	6.7	ppb		
22300-003-SWB	Sink with Bubblers in Kindergarten Classroom 003	0.8	ppb		
22300-001-S	Sink in Kindergarten Classroom 001	10.3	ppb		
22300-001-SWB	Sink with Bubblers in Kindergarten Classroom 001	3.7	ppb		
22300-002-SWB	Sink with Bubblers in Classroom 002	1.0	ppb		
22300-002-S	Sink in Classroom 002	3.0	ppb		
22300-004-S	Sink in Classroom 004	62.9	ppb	0.8	ppb
22300-004-SWB	Sink with Bubblers in Classroom 004	0.8	ppb		
22300-006-SWB	Sink with Bubblers in Classroom 006	1.0	ppb		
22300-006-S	Sink in Classroom 006	3.0	ppb		
22300-504-S	Sink in Teacher's Lounge	0.1	ppb		
22300-134H-DF	Hallway Drinking Fountain outside of Teacher's Lounge	<0.1 *	ppb		
22300-469-S	Sink in Work Room 469	1.0	ppb		
22300-938-S1	Art Room Sink	1.5	ppb		
22300-938-S2	Art Room Sink	1.8	ppb		
22300-199-S	Sink in Music Room	6.4	ppb		
22300-153-S1	Food Service Sink-Rinse/Wash	1.1	ppb		
22300-153-S2	Food Service Sink-Food Prep	9.7	ppb		
22300-153-S3	Food Service Sink-Food Prep	2.8	ppb		
22300-153-S4	Food Service Sink-Hand Sink	0.3	ppb		
22300-153-S5	Food Service Sink-Sprayer	6.6	ppb		
22300-147H-DFL	Hallway Drinking Fountain outside of Cafeteria/Left	<0.1 *	ppb		
22300-147H-DFR	Hallway Drinking Fountain outside of Cafeteria/Right	0.1	ppb		
22300-175-S	Sink in Library Work Room	0.6	ppb		
22300-165H-DF	Hallway Drinking Fountain outside of Library	0.2	ppb		
22300-011-S	Sink in Classroom 011	12.9	ppb		
22300-011-SWB	Sink with Bubblers in Classroom 011	6.3	ppb		
22300-R1-098-DF	Drinking Fountain in TEMP R1-098	5.4	ppb		
22300-R1-090-DF	Drinking Fountain in TEMP R1-090	23.3	ppb		Repairs Pending
22300-013-S	Sink in Classroom 013	0.6***	ppb		
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.					
** Resampling results after elevated fixtures were removed and replaced.					
*** This fixture was sampled on 11/9/16.					