

Lasley Elementary School - Sampled 7/8/16			
CustomerSampleNumber	Description	Lead Result	Units
22500-135H-DFL	Hallway Drinking Fountain near Art Room/Left	0.4	ppb
22500-135H-DFR	Hallway Drinking Fountain near Art Room/Right	0.5	ppb
22500-132-S	Sink in Classroom 132	1.3	ppb
22500-132-SWB	Sink with Bubblers in Classroom 132	0.6	ppb
22500-130-S	Sink in Classroom 130	2.2	ppb
22500-130-SWB	Sink with Bubblers in Classroom 130	1.0	ppb
22500-128-S	Sink in Classroom 128	1.2	ppb
22500-128-SWB	Sink with Bubblers in Classroom 128	0.2	ppb
22500-109-S	Sink in the Prep/Work Room near Classroom 114	71.7	ppb
22500-114-S	Sink in Classroom 114	2.2	ppb
22500-114-SWB	Sink with Bubblers in Classroom 114	1.0	ppb
22500-113H-DF	Hallway Drinking Fountain near Classroom 114	2.1	ppb
22500-107-S	Sink in Classroom 107	12.2	ppb
22500-105-S	Sink in Classroom 105	5.3	ppb
22500-105-SWB	Sink with Bubblers in Classroom 105	1.3	ppb
22500-103-S	Sink in Classroom 103	4.3	ppb
22500-103-SWB	Sink with Bubblers in Classroom 103	7.2	ppb
22500-101-S	Sink in Classroom 101	21.5	ppb
22500-101-SWB	Sink with Bubblers in Classroom 101	5.6	ppb
22500-102-S	Sink in Classroom 102	5.5	ppb
22500-102-SWB	Sink with Bubblers in Classroom 102	2.0	ppb
22500-104-S	Sink in Classroom 104	4.1	ppb
22500-104-SWB	Sink with Bubblers in Classroom 104	4.7	ppb
22500-106-S	Sink in Classroom 106	3.3	ppb
22500-106-SWB	Sink with Bubblers in Classroom 106	1.0	ppb
22500-118-S	Sink in Classroom 118	2.6	ppb
22500-118-SWB	Sink with Bubblers in Classroom 118	<0.1 *	ppb
22500-119-S	Sink in Classroom 119	2.1	ppb
22500-119-SWB	Sink with Bubblers in Classroom 119	<0.1 *	ppb
22500-120H-DF	Hallway Drinking Fountain near Classroom 125	0.3	ppb
22500-125-S	Sink in Classroom 125	5.0	ppb
22500-125-SWB	Sink with Bubblers in Classroom 125	<0.1 *	ppb
22500-126-S	Sink in Classroom 126	3.2	ppb
22500-126-SWB	Sink with Bubblers in Classroom 126	<0.1 *	ppb
22500-127-S	Sink in Classroom 127	50.3	ppb
22500-127-SWB	Sink with Bubblers in Classroom 127	0.6	ppb
22500-129-S	Sink in Classroom 129	1.2	ppb
22500-129-SWB	Sink with Bubblers in Classroom 129	0.6	ppb
22500-131-S	Sink in Classroom 131	2.9	ppb
22500-131-SWB	Sink with Bubblers in Classroom 131	2.4	ppb
22500-133-S	Sink in Classroom 133	1.6	ppb
22500-133-SWB	Sink with Bubblers in Classroom 133	0.7	ppb
22500-161-S	Art Room Sink	1.5	ppb
22500-166-DF	Drinking Fountain in Cafeteria	11.2	ppb
22500-167-S1	Food Service Sink-Hand Sink	8.0	ppb

22500-167-S2	Food Service Sink-Food Prep	5.8	ppb
22500-167-S3	Food Service Sink-Wash/Rinse	4.9	ppb
22500-167-S4	Food Service Sink-Wash/Rinse	6.9	ppb
22500-172-S	Sink in Music Room	0.9	ppb
22500-172-SWB	Sink with Bubbler in Music Room	0.5	ppb
22500-100H-DF	Hallway Drinking Fountain near Music Room	1.6	ppb
22500-107-SWB	Sink with Bubbler in Classroom 107	2.1	ppb
22500-R1-081-DF	Drinking Fountain in TEMP R1-081	18.2	ppb
22500-R1-200-DF	Drinking Fountain in TEMP R1-200	1.8	ppb
22500-167-S5	Food Service Sink-Sprayer	9.4	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.			