

Leawood Elementary School - Sampled 6/22/16			
CustomerSampleNumber	Description	Lead Result	Units
23200-E145H-DF	Hallway Drinking Fountain near Main Entrance	16.5	ppb
23200-E146-S1	Sink in Pre-K Classroom E146	0.9	ppb
23200-E146-S2	Sink in Pre-K Classroom E146	8.1	ppb
23200-E148H-SWB	Hallway Sink with Bubbler near Computer Lab	0.4	ppb
23200-E148AH-SWB1	Hallway Sink with Bubbler near Classroom E164C	0.7	ppb
23200-E148AH-SWB2	Hallway Sink with Bubbler near Classroom E164A	0.8	ppb
23200-E115-S1	Food Service Sink	14.3	ppb
23200-E115-S2	Food Service Sink-Wash/Rinse/Sanitize	12.2	ppb
23200-E115-S3	Food Service Sink-Wash/Rinse	17.2	ppb
23200-E113-S	Food Service Sink-Food Prep	24.8	ppb
23200-179-DF	Drinking Fountain in Cafeteria	2.6	ppb
23200-E159H-SWB	Hallway Sink with Bubbler across from Kitchen	1.6	ppb
23200-E162-S	Sink in Science Room	20.0	ppb
23200-E126H-DF	Hallway Drinking Fountain near Music Room	5.3	ppb
23200-182-S1	Art Room Sink	0.9	ppb
23200-182-S2	Art Room Sink	0.4	ppb
23200-182-S3	Art Room Sink	0.6	ppb
23200-182-S4	Art Room Sink	0.6	ppb
23200-194H-DFL	Hallway Drinking Fountain near Classroom 185/Left	0.2	ppb
23200-194H-DFR	Hallway Drinking Fountain near Classroom 185/Right	0.2	ppb
23200-185-SWB	Sink with Bubbler in Classroom 185	0.2	ppb
23200-188-SWB	Sink with Bubbler in Classroom 188	0.4	ppb
23200-189-SWB	Sink with Bubbler in Classroom 189	1.8	ppb
23200-190-SWB	Sink with Bubbler in Classroom 190	0.2	ppb
23200-191-SWB	Sink with Bubbler in Classroom 191	< 0.1 *	ppb
23200-192-SWB	Sink with Bubbler in Classroom 192	0.1	ppb
23200-193-SWB	Sink with Bubbler in Classroom 193	0.3	ppb
23200-E124D-S	Sink in Office E124D	1.6	ppb
23200-E124H-DF	Hallway Drinking Fountain near Gym	0.5	ppb
23200-E126D-S	Sink in Clinic	0.8	ppb
23200-E101-SWB	Sink with Bubbler in Kindergarten Classroom E101	2.9	ppb
23200-E104-SWB	Sink with Bubbler in Kindergarten Classroom E104	2.9	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.			