

| McLain Community School - Sampled 7/29/16 | | | |
|---|---|-------------|-------|
| CustomerSampleNumber | Description | Lead Result | Units |
| 52700-130-S1 | Sink in Child Lab 130 | 1.8 | ppb |
| 52700-130-S2 | Sink in Child Lab 130 | 0.9 | ppb |
| 52700-133-S1 | Sink in Child Lab 133 | 1.3 | ppb |
| 52700-133-S2 | Sink in Child Lab 133 | 1.9 | ppb |
| 52700-135-S1 | Sink in Child Lab 135 | 2.0 | ppb |
| 52700-135-S2 | Sink in Child Lab 135 | 1.7 | ppb |
| 52700-137-S1 | Sink in Computer Room 137 | 3.8 | ppb |
| 52700-137-S2 | Sink in Computer Room 137 | 2.1 | ppb |
| 52700-136-S1 | Hand Washing Sink in Child Lab 136 | 3.2 | ppb |
| 52700-136-S2 | Food Prep Sink in Child Lab 136 | 2.6 | ppb |
| 52700-134-S1 | Hand Washing Sink in Child Lab 134 | 1.5 | ppb |
| 52700-134-S2 | Food Prep Sink in Child Lab 134 | 0.9 | ppb |
| 52700-132-S1 | Hand Washing Sink in Child Lab 132 | 6.1 | ppb |
| 52700-132-S2 | Food Prep Sink in Child Lab 132 | 1.7 | ppb |
| 52700-131-S1 | Bottle Prep Sink in Child Lab 131 | 2.9 | ppb |
| 52700-131-S2 | Hand Washing Sink in Child Lab 131 | 2.1 | ppb |
| 52700-119-S | Sink in Planning Room 119 | 0.6 | ppb |
| 52700-117-S | Sink in Clinic | 1.0 | ppb |
| 52700-1DH-DFL | Hallway Drinking Fountain across from Classroom 110/Left | 1.2 | ppb |
| 52700-1DH-DFR | Hallway Drinking Fountain across from Classroom 110/Right | 0.3 | ppb |
| 52700-104-S1 | Sink in FACS Lab | 1.9 | ppb |
| 52700-104-S2 | Sink in FACS Lab | 1.5 | ppb |
| 52700-104-S3 | Sink in FACS Lab | 2.9 | ppb |
| 52700-104-S4 | Sink in FACS Lab | 2.5 | ppb |
| 52700-104-S5 | Sink in FACS Lab | 1.4 | ppb |
| 52700-104B-S | Sink in Laundry Room | 0.8 | ppb |
| 52700-102-S1 | Sink in Laboratory Room 102 | 0.5 | ppb |
| 52700-102-S2 | Sink in Laboratory Room 102 | 0.6 | ppb |
| 52700-102-S3 | Sink in Laboratory Room 102 | 0.8 | ppb |
| 52700-139A-S | Sink in Science Prep Room | 0.6 | ppb |