

Moore Middle School - Sampled 8/5/16			
CustomerSampleNumber	Description	Lead Result	Units
67600-118-S	Sink in Clinic	2.5	ppb
67600-130-S	Sink in Planning Room 130	2.0	ppb
67600-143-S1	Sink in Food Lab 143	5.1	ppb
67600-143-S2	Sink in Food Lab 143	67.3	ppb
67600-143-S3	Sink in Food Lab 143	7.1	ppb
67600-143-S4	Sink in Food Lab 143	9.1	ppb
67600-143-S5	Sink in Food Lab 143	5.4	ppb
67600-143-S6	Sink in Food Lab 143	7.8	ppb
67600-143-S7	Sink in Food Lab 143	6.9	ppb
67600-107-S	Sink in Clothing Lab 107	2.4	ppb
67600-107-SWB	Sink with Bubbler in Clothing Lab 107	6.5	ppb
67600-142-S	Sink in Teacher's Lounge	1.0	ppb
67600-144-S1	Food Service Sink-Hand Sink	3.6	ppb
67600-144-S2	Food Service Sink-Food Prep	5.6	ppb
67600-144-S3	Food Service Sink-Sprayer	22.2	ppb
67600-144-S4	Food Service Sink-Wash	5.8	ppb
67600-144-S5	Food Service Sink	3.6	ppb
67600-144-S6	Food Service Sink	1.8	ppb
67600-111-S1	Sink in Drama Room 111	8.0	ppb
67600-111-S2	Sink in Drama Room 111	24.8	ppb
67600-111-SWB	Sink with Bubbler in Drama Room 111	7.0	ppb
67600-113-S	Sink in Small Shop Room 113	2.4	ppb
67600-117-S1	Sink in Art Room 117	9.9	ppb
67600-117-S2	Sink in Art Room 117	6.4	ppb
67600-201X-S	Sink in Technology Lab 201X	5.6	ppb
67600-167-DF	Drinking Fountain in Boy's Locker Room	2.1	ppb
67600-180-S	Sink in PE Storage Room	22.1	ppb
67600-181-DF	Drinking Fountain in Girl's Locker Room	2.8	ppb
67600-186H-DF	Hallway Drinking Fountain across from Drama Room 111	0.6	ppb
67600-104-S	Sink in Music Room 104	2.0	ppb
67600-200X-S	Sink in Band Room 200X	3.2	ppb
67600-200X-SWB	Sink with Bubbler in Band Room 200X	4.3	ppb
67600-107XH-DF	Hallway Drinking Fountain across from Attendance Office	1.0	ppb
67600-290H-DF	Hallway Drinking Fountain across from Classroom 217	0.8	ppb
67600-212-S1	Sink in Science Room 212	1.8	ppb
67600-212-S2	Sink in Science Room 212	7.2	ppb
67600-212-S3	Sink in Science Room 212	2.2	ppb
67600-212-S4	Sink in Science Room 212	2.0	ppb
67600-214-S1	Sink in Science Room 214	3.4	ppb
67600-214-S2	Sink in Science Room 214	8.3	ppb
67600-214-S3	Sink in Science Room 214	4.0	ppb
67600-214-S4	Sink in Science Room 214	7.6	ppb

67600-210X-S	Sink in Planning Room 210X	3.9	ppb
67600-210H-DF	Hallway Drinking Fountain outside of Science Room210	1.6	ppb
67600-210-S1	Sink in Science Room 210	4.0	ppb
67600-210-S2	Sink in Science Room 210	2.8	ppb
67600-210-S3	Sink in Science Room 210	7.4	ppb
67600-210-S4	Sink in Science Room 210	4.5	ppb
67600-208-S1	Sink in Science Room 208	4.1	ppb
67600-208-S2	Sink in Science Room 208	2.1	ppb
67600-208-S3	Sink in Science Room 208	4.5	ppb
67600-208-S4	Sink in Science Room 208	3.9	ppb
67600-206-S	Sink in Classroom 206	1.1	ppb
67600-230-S	Sink in Processing Room 230	9.5	ppb