

Mortensen Elementary School - Sampled 7/24/16				Resampled** 11/18/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
29000-A102H-DFL	Hallway Drinking Fountain Outside of Classroom 001/Left	0.1	ppb		
29000-A102H-DFR	Hallway Drinking Fountain Outside of Classroom 001/Right	0.2	ppb		
29000-001-S	Sink in Classroom 001	12.7	ppb		
29000-001-SWB	Sink with Bubblers in Classroom 001	0.4	ppb		
29000-002-S	Sink in Classroom 002	2.3	ppb		
29000-002-SWB	Sink with Bubblers in Classroom 002	1.6	ppb		
29000-003-S	Sink in Classroom 003	6.7	ppb		
29000-003-SWB	Sink with Bubblers in Classroom 003	1.1	ppb		
29000-004-S	Sink in Classroom 004	10.6	ppb		
29000-004-SWB	Sink with Bubblers in Classroom 004	1.3	ppb		
29000-005-S	Sink in Classroom 005	4.6	ppb		
29000-005-SWB	Sink with Bubblers in Classroom 005	<0.1 *	ppb		
29000-006-S	Sink in Classroom 006	7.1	ppb		
29000-006-SWB	Sink with Bubblers in Classroom 006	0.5	ppb		
29000-007-S	Sink in Classroom 007	4.7	ppb		
29000-007-SWB	Sink with Bubblers in Classroom 007	2.4	ppb		
29000-008-S	Sink in Classroom 008	0.2	ppb		
29000-008-SWB	Sink with Bubblers in Classroom 008	7.0	ppb		
29000-009-S	Sink in Classroom 009	4.2	ppb		
29000-009-SWB	Sink with Bubblers in Classroom 009	1.8	ppb		
29000-010-S	Sink in Classroom 010	12.5	ppb		
29000-010-SWB	Sink with Bubblers in Classroom 010	0.5	ppb		
29000-011-S	Sink in Classroom 011	1.1	ppb		
29000-011-SWB	Sink with Bubblers in Classroom 011	1.6	ppb		
29000-012-S	Sink in Classroom 012	2.3	ppb		
29000-012-SWB	Sink with Bubblers in Classroom 012	0.3	ppb		
29000-013-S	Sink in Classroom 013	0.2	ppb		
29000-013-SWB	Sink with Bubblers in Classroom 013	7.5	ppb		
29000-014-S	Sink in Classroom 014	8.7	ppb		
29000-014-SWB	Sink with Bubblers in Classroom 014	0.3	ppb		
29000-A152-S	Sink in Teacher's Lounge	2.2	ppb		
29000-015-S	Sink in Pre-K Classroom 015	7.3	ppb		
29000-015-SWB	Sink with Bubblers in Pre-K Classroom 015	0.4	ppb		
29000-016-S	Sink in Kindergarten Classroom 016	12.0	ppb		
29000-016-SWB	Sink with Bubblers in Kindergarten Classroom 016	0.9	ppb		
29000-017-S	Sink in Kindergarten Classroom 017	13.5	ppb		
29000-017-SWB	Sink with Bubblers in Kindergarten Classroom 017	0.3	ppb		
29000-018-S	Sink in Kindergarten Classroom 018	11.0	ppb		
29000-018-SWB	Sink with Bubblers in Kindergarten Classroom 018	0.2	ppb		
29000-B102H-DFL	Hallway Drinking Fountain by Music Room/Left	0.2	ppb		
29000-B102H-DFR	Hallway Drinking Fountain by Music Room/Right	1.2	ppb		
29000-019-S	Sink in Classroom 019	6.6	ppb		
29000-019-SWB	Sink with Bubblers in Classroom 019	0.4	ppb		
29000-020-S	Sink in Classroom 020	4.9	ppb		
29000-020-SWB	Sink with Bubblers in Classroom 020	11.8	ppb		
29000-021-S	Sink in Classroom 021	3.4	ppb		
29000-021-SWB	Sink with Bubblers in Classroom 021	0.4	ppb		
29000-022-S	Sink in Classroom 022	9.9	ppb		
29000-022-SWB	Sink with Bubblers in Classroom 022	0.1	ppb		
29000-023-S	Sink in Classroom 023	8.9	ppb		
29000-023-SWB	Sink with Bubblers in Classroom 023	0.6	ppb		
29000-024-S	Sink in Classroom 024	10.6	ppb		
29000-024-SWB	Sink with Bubblers in Classroom 024	0.7	ppb		
29000-B128-S1	Food Service Sink-Sprayer	4.0	ppb		
29000-B127-S1	Food Service Sink-Wash/Rinse	6.6	ppb		
29000-B127-S2	Food Service Sink-Rinse/Sanitize	15.2	ppb	2.9	ppb
29000-B127-S3	Food Service Sink-Food Prep	3.2	ppb		
29000-B127-S4	Food Service Sink-Hand Sink	4.3	ppb		
29000-A156-S1	Art Room Sink	1.4	ppb		

29000-A156-S2	Art Room Sink	0.9	ppb	
29000-A159-S	Sink in Work Room A159	4.9	ppb	
29000-A162-S	Sink in Clinic	3.4	ppb	
29000-B128-S2	Food Service Sink	4.1***	ppb	
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.				
** Resampling results after elevated fixtures were removed and replaced.				
*** This fixture was sampled on 11/18/16.				