

North Arvada Middle School - Sampled 8/5/16			
CustomerSampleNumber	Description	Lead Result	Units
67900-307H-DFL	Hallway Drinking Fountain across from Main Office/Left	1.4	ppb
67900-307H-DFR	Hallway Drinking Fountain across from Main Office/Right	1.7	ppb
67900-306-S	Sink in Library Work Room	17.2	ppb
67900-407H-DFL	Hallway Drinking Fountain across from Lab B10/Left	1.7	ppb
67900-B9-S1	Sink in Science Lab B10	2.5	ppb
67900-B9-S2	Sink in Science Lab B10	4.3	ppb
67900-B9-S3	Sink in Science Lab B10	8.8	ppb
67900-B9-S4	Sink in Science Lab B10	11.9	ppb
67900-B9-S5	Sink in Science Lab B10	13.3	ppb
67900-404-S	Sink in Science Prep Room 404	5.1	ppb
67900-B10-S1	Sink in Science Lab B10	21.6	ppb
67900-B10-S2	Sink in Science Lab B10	9.8	ppb
67900-B10-S3	Sink in Science Lab B10	4.2	ppb
67900-B10-S4	Sink in Science Lab B10	3.1	ppb
67900-B10-S5	Sink in Science Lab B10	4.5	ppb
67900-B12-S1	Sink in Science Lab B11	17.3	ppb
67900-B12-S2	Sink in Science Lab B11	15.6	ppb
67900-B12-S3	Sink in Science Lab B11	56.3	ppb
67900-B12-S4	Sink in Science Lab B11	12.6	ppb
67900-B12-S5	Sink in Science Lab B11	26.1	ppb
67900-C9-S1	Sink in Consumer Science C9	3.9	ppb
67900-C9-S2	Sink in Consumer Science C9	6.3	ppb
67900-C9-S3	Sink in Consumer Science C9	2.7	ppb
67900-C9-S4	Sink in Consumer Science C9	2.8	ppb
67900-C9-S5	Sink in Consumer Science C9	13.9	ppb
67900-C9-S6	Sink in Consumer Science C9	4.8	ppb
67900-C9-S7	Sink in Consumer Science C9	5.2	ppb
67900-C8-S	Sink in Family and Consumer Science Kitchen C8	23.9	ppb
67900-C2-S1	Sink in Science Lab C2	3.8	ppb
67900-C2-S2	Sink in Science Lab C2	6.2	ppb
67900-C2-S3	Sink in Science Lab C2	27.9	ppb
67900-C2-S4	Sink in Science Lab C2	6.1	ppb
67900-C2-S5	Sink in Science Lab C2	5.5	ppb
67900-A10-S1	Sink in Science Lab A10	25.9	ppb
67900-A10-S3	Sink in Science Lab A10	36.5	ppb
67900-430-S	Sink in Planning Room 430	3.2	ppb
67900-A9-S1	Sink in Science Lab A9	17.3	ppb
67900-A9-S2	Sink in Science Lab A9	8.4	ppb
67900-A9-S3	Sink in Science Lab A9	3.4	ppb
67900-A9-S4	Sink in Science Lab A9	20.0	ppb
67900-A9-S5	Sink in Science Lab A9	12.0	ppb
67900-433H-DFL	Hallway Drinking Fountain across from Lab A9/Left	0.6	ppb

67900-433H-DFR	Hallway Drinking Fountain across from Lab A9/Right	3.5	ppb
67900-AR1-S1	Sink in Art Room AR1	23.0	ppb
67900-AR1-S2	Sink in Art Room AR1	4.5	ppb
67900-AR1-S3	Sink in Art Room AR1	8.6	ppb
67900-AR1-S4	Sink in Art Room AR1	33.1	ppb
67900-AR1-S5	Sink in Art Room AR1	15.1	ppb
67900-AR1-S6	Sink in Art Room AR1	7.6	ppb
67900-AR1-S7	Sink in Art Room AR1	1.1	ppb
67900-AR1-S8	Sink in Art Room AR1	0.9	ppb
67900-AR2-S1	Sink in Art Room AR2	14.1	ppb
67900-AR2-S3	Sink in Art Room AR2	3.4	ppb
67900-AR2-S4	Sink in Art Room AR2	4.3	ppb
67900-AR2-S5	Sink in Art Room AR2	50.5	ppb
67900-AR2-S6	Sink in Art Room AR2	9.5	ppb
67900-AR2-S7	Sink in Art Room AR2	12.2	ppb
67900-AR2-S8	Sink in Art Room AR2	19.2	ppb
67900-335A-S	Sink in Dark Room	1.3	ppb
67900-318-S	Sink in Teacher's Lounge	1.3	ppb
67900-337H-S	Hallway Sink across from Clinic	1.3	ppb
67900-311-S	Sink in Clinic	3.4	ppb
67900-M1-DF	Drinking Fountain in Music Room M1	0.6	ppb
67900-M2-S	Sink in Band Room	3.5	ppb
67900-M2-SWB	Sink with Bubbler in Band Room	0.6	ppb
67900-WR-S	Sink in Weight Room	10.2	ppb
67900-WR-DF	Drinking Fountain in Weight Room	2.4	ppb
67900-BL-S	Sink in Boy's Locker Room	2.3	ppb
67900-GYM1H-DF	Hallway Drinking Fountain by the Gym	0.3	ppb
67900-GL-S	Sink in Girl's Locker Room	2.0	ppb
67900-GL-DF	Drinking Fountain in Girl's Locker Room	0.6	ppb
67900-TA2-S	Sink in Tech Arts Room 2	4.5	ppb
67900-218A-S	Sink in Tech Arts Room 2 Office	13.0	ppb
67900-232H-DF	Hallway Drinking Fountain across from Cafeteria	0.7	ppb
67900-225-S1	Food Service Sink-Sprayer	4.2	ppb
67900-225-S2	Food Service Sink-Wash	6.0	ppb
67900-225-S3	Food Service Sink-Wash	3.4	ppb
67900-225-S4	Food Service Sink-Hand Sink	0.4	ppb
67900-225-S5	Food Service Sink-Food Prep	5.0	ppb
67900-CAFÉ-DF	Drinking Fountain in Cafeteria	0.5	ppb