

Parmalee Elementary School - Sampled 6/21/16			
CustomerSampleNumber	Description	Lead Result	Units
32300-108-S	Sink in Clinic	3.9	ppb
32300-109-S	Sink in Clinic Restroom	6.4	ppb
32300-111-S	Sink in Teacher's Lounge	1.9	ppb
32300-113-SWB	Sink with Bubblers in Kindergarten Classroom 113	3.6	ppb
32300-128H-DF	Hallway Drinking Fountain Near Office	3.6	ppb
32300-131-S1	Food Service Sink-Sanitize, Wash, Rinse	5.2	ppb
32300-131-S2	Food Service Sink-Food Prep	25.7	ppb
32300-131-S3	Food Service Sink-Hand Sink	17.6	ppb
32300-135H-DF	Hallway Drinking Fountain Near Computer Lab	2.4	ppb
32300-151-SWB	Sink with Bubblers in Library Workroom	25.2	ppb
32300-158-SWB	Sink with Bubblers in Classroom 158	0.5	ppb
32300-167-SWB	Sink with Bubblers in Classroom 167	0.8	ppb
32300-171-SWB	Sink with Bubblers in Classroom 171	0.5	ppb
32300-172-SWB	Sink with Bubblers in Classroom 172	0.9	ppb
32300-176-SWB	Sink with Bubblers in Classroom 176	1.0	ppb
32300-178-S1	Art Room Sink	1.7	ppb
32300-178-S2	Art Room Sink	1.5	ppb
32300-168-SWB	Sink with Bubblers in Classroom 168	0.7	ppb
32300-166-SWB	Sink with Bubblers in Classroom 166	1.7	ppb
32300-159-SWB	Sink with Bubblers in Classroom 159	3.9	ppb
32300-154-SWB	Sink with Bubblers in Kindergarten Classroom 154	6.1	ppb
32300-RE-002-S1	Sink in Temp RE-002	5.0	ppb
32300-RE-002-S2	Sink in Temp RE-002	9.0	ppb
32300-RE-002-DF	Drinking Fountain in Temp RE-002	3.8	ppb
32300-RE-057-S1	Sink in Temp RE-057	2.2	ppb
32300-RE-057-S2	Sink in Temp RE-057	1.9	ppb
32300-RE-057-DF	Drinking Fountain in Temp RE-057	3.6	ppb
32300-REC-083-DF	Drinking Fountain in Temp REC-083	2.6	ppb
32300-REC-083-S1	Sink in Temp REC-083	4.3	ppb
32300-REC-083-S2	Sink in Temp REC-083	6.7	ppb
32300-RE-044-DF	Drinking Fountain in Temp RE-044	3.8	ppb
32300-RE-044-S	Sink in Temp RE-044	3.3	ppb