

Patterson International - Sampled 6/21/16				Resampled** 9/7/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
32400-B07H-DF	Hallway Drinking Fountain near Lobby	0.3	ppb		
32400-209-S1	Art Room Sink	2.7	ppb		
32400-209-S2	Art Room Sink	7.2	ppb		
32400-C09-S1	Sink in Hallway near Classroom 310	2.5	ppb		
32400-C09-SWB1	Sink with Bubbler in Hallway near Classroom 310	0.8	ppb		
32400-C09-S2	Sink in Hallway near Classroom 309	5.4	ppb		
32400-C09-SWB2	Sink with Bubbler in Hallway near Classroom 309	1.6	ppb		
32400-C06-S1	Sink in Hallway near Classroom 308	11.7	ppb		
32400-C06-SWB1	Sink with Bubbler in Hallway near Classroom 308	2.6	ppb		
32400-C06-S2	Sink in Hallway near Classroom 306	6.6	ppb		
32400-C06-SWB2	Sink with Bubbler in Hallway near Classroom 306	2.7	ppb		
32400-307-S	Sink in Teacher's Lounge	15.3	ppb	14.3	ppb
32400-307-SWB	Sink with Bubbler in Teacher's Lounge	19.7	ppb	3.7	ppb
32400-C32-S1	Sink in Hallway near Classroom 304	4.2	ppb		
32400-C32-SWB1	Sink with Bubbler in Hallway near Classroom 304	1.5	ppb		
32400-C32-S2	Sink in Hallway near Classroom 302	4.7	ppb		
32400-C32-SWB2	Sink with Bubbler in Hallway near Classroom 302	1.4	ppb		
32400-C11-S	Sink in Library Workroom	5.6	ppb		
32400-C41-S1	Sink in Hallway near Classroom 301	3.2	ppb		
32400-C41-SWB1	Sink with Bubbler in Hallway near Classroom 301	0.9	ppb		
32400-C41-S2	Sink in Hallway near Classroom 312	3.1	ppb		
32400-C41-SWB2	Sink with Bubbler in Hallway near Classroom 312	1.2	ppb		
32400-208-S	Sink in Classroom 208	2.6	ppb		
32400-208-SWB	Sink with Bubbler in Classroom 208	1.6	ppb		
32400-207-S	Sink in Classroom 207	9.7	ppb		
32400-207-SWB	Sink with Bubbler in Classroom 207	16.8	ppb	1.0	ppb
32400-206-S	Sink in Classroom 206	4.6	ppb		
32400-206-SWB	Sink with Bubbler in Classroom 206	3.7	ppb		
32400-205-S	Sink in Classroom 205	6.3	ppb		
32400-205-SWB	Sink with Bubbler in Classroom 205	2.3	ppb		
32400-204-S	Sink in Classroom 204	9.8	ppb		
32400-204-SWB	Sink with Bubbler in Classroom 204	3.9	ppb		
32400-203-S	Sink in Kindergarten Classroom 203	5.7	ppb		
32400-203-SWB	Sink with Bubbler in Kindergarten Classroom 203	5.6	ppb		
32400-A27-S1	Food Service Sink-Food Prep Sink	5.0	ppb		
32400-A27-S2	Food Service Sink-Hand Sink	15.2	ppb	Repairs Pending	
32400-A27-S3	Food Service Sink-Wash	9.4	ppb		
32400-A27-S4	Food Service Sink-Rinse	7.2	ppb		
32400-102-S	Sink in Kindergarten Classroom 102	20.9	ppb	10.5	ppb
32400-102-SWB	Sink with Bubbler in Kindergarten Classroom 102	3.2	ppb		
32400-100-S	Sink in Kindergarten Classroom 100	6.5	ppb		
32400-100-SWB	Sink with Bubbler in Kindergarten Classroom 100	2.6	ppb		
32400-101-S	Sink in Classroom 101	2.1	ppb		
32400-101-SWB	Sink with Bubbler in Classroom 101	1.6	ppb		
32400-103-S	Sink in Classroom 103	2.2	ppb		
32400-103-SWB	Sink with Bubbler in Classroom 103	1.1	ppb		
32400-105-S	Sink in Clinic	3.2	ppb		

\*\* Resampling results after elevated fixtures were repaired, or removed and replaced.