

Peck Elementary School - Sampled 6/17/16			
CustomerSampleNumber	Description	Lead Result	Units
32600-104-S	Sink in Clinic	13.1	ppb
32600-104A-S	Sink in Clinic Restroom	3.1	ppb
32600-106-S	Sink in Teacher's Lounge	3.8	ppb
32600-154X-S	Sink in Restroom near Teacher's Lounge	34.3	ppb
32600-113-S1	Food Service Sink-Food Prep	7.8	ppb
32600-113-S2	Food Service Sink-Hand Sink	31.2	ppb
32600-115X-S1	Food Service Sink-Sanitize/Rinse	37.4	ppb
32600-115-S2	Food Service Sink-Rinse/Wash	18.6	ppb
32600-112XH-DF	Hallway Drinking Fountain near Cafeteria	0.1	ppb
32600-16-S	Sink in Classroom 16	13.9	ppb
32600-15-S	Sink in Classroom 15	7.2	ppb
32600-17-S	Sink in Classroom 17	12.6	ppb
32600-17-SWB	Sink with Bubbler in Classroom 17	1.0	ppb
32600-15-SWB	Sink with Bubbler in Classroom 15	9.1	ppb
32600-104XH-DF	Hallway Drinking Fountain	0.9	ppb
32600-14-SWB	Sink with Bubbler in Classroom 14	5.0	ppb
32600-14-S	Sink in Classroom 14	16.2	ppb
32600-13-SWB	Sink with Bubbler in Classroom 13	2.9	ppb
32600-13-S	Sink in Classroom 13	16.5	ppb
32600-12-SWB	Sink with Bubbler in Classroom 12	1.8	ppb
32600-12-S	Sink in Classroom 12	13.2	ppb
32600-11-S	Sink in Classroom 11	3.9	ppb
32600-11-SWB	Sink with Bubbler in Classroom 11	0.4	ppb
32600-10-S	Sink in Classroom 10	1.6	ppb
32600-10-SWB	Sink with Bubbler in Classroom 10	23.2	ppb
32600-9-S	Sink in Classroom 9	10.2	ppb
32600-8-S	Sink in Classroom 8	5.1	ppb
32600-8-SWB	Sink with Bubbler in Classroom 8	2.8	ppb
32600-155X-S	Sink in Resource Room	16.5	ppb
32600-7-SWB	Sink with Bubbler in Classroom 7	8.7	ppb
32600-7-S	Sink in Classroom 7	8.5	ppb
32600-6-S	Sink in Classroom 6	8.8	ppb
32600-6-SWB	Sink with Bubbler in Classroom 6	1.9	ppb
32600-5-S	Sink in Classroom 5	4.2	ppb
32600-5-SWB	Sink with Bubbler in Classroom 5	1.0	ppb
32600-4-SWB	Sink with Bubbler in Classroom 4	0.5	ppb
32600-4-S	Sink in Classroom 4	3.2	ppb
32600-3-S	Sink in Classroom 3	12.0	ppb
32600-3-SWB	Sink with Bubbler in Classroom 3	1.8	ppb
32600-2-S	Sink in Classroom 2	152.3	ppb
32600-113XH-DF	Hallway Drinking Fountain	0.3	ppb
32600-1-SWB	Sink with Bubbler in Classroom 1	2.6	ppb

32600-1-S	Sink in Classroom 1	6.9	ppb
32600-102A-S	Sink in Library Workroom	5.7	ppb
32600-021-S	Sink in Classroom 21	75.7	ppb
32600-021-SWB	Sink with Bubbler in Classroom 21	5.5	ppb
32600-020-S	Sink in Classroom 20	8.8	ppb
32600-020-SWB	Sink with Bubbler in Classroom 20	9.0	ppb
32600-005-S4	Art Room Sink	6.9	ppb
32600-005-S1	Art Room Sink	6.0	ppb
32600-005-S3	Art Room Sink	5.6	ppb
32600-011H-DF	Hallway Drinking Fountain in Basement near stairs	10.3	ppb
32600-003-S	Sink in Music Room	3.3	ppb
32600-024XH-DF	Hallway Drinking Fountain in Basement near Gym	<0.1 *	ppb
32600-R1-149-S	Sink in Temp R1-149	2.4	ppb
32600-R1-149-DF	Drinking Fountain in Temp R1-149	14.8	ppb
32600-9-SWB	Sink with Bubbler in Classroom 9	1.2	ppb
32600-005-S2	Sink in Art Room	9.0	ppb
32600-16-SWB	Sink with Bubbler in Room 16	1.7	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.			