

Pomona High School - Sampled 9/13/16				Resampled** 12/6/16	
CustomerSampleNumber	Description	Lead Result	Unit	Lead Result	Units
78000-634-S	Sink in Workroom 634 in Main Office Area	4.1	ppb		
78000-622-S	Sink in Clinic	10.9	ppb		
78000-550-S	Sink in Planning Room 550 (next to Classroom 547 in the English Area)	4.1	ppb		
78000-525-S	Sink in Library Workroom	1.1	ppb		
78000-603H-DFL	Hallway Drinking Fountain Outside of Small Auditorium/Left	1.6	ppb		
78000-603H-DFR	Hallway Drinking Fountain Outside of Small Auditorium/Right	0.1	ppb		
78000-509-S	Sink in Counseling Room 509	3.7	ppb		
78000-505-S	Sink in Classroom 505	6.7	ppb		
78000-232-S	Sink in Office 232 (across from Classroom 215 in the Math Area)	2.0	ppb		
78000-228-S	Sink in Office 228 (next to Classroom 226 in the Business Ed. Area)	11.4	ppb		
78000-402-S	Sink in Science Prep Area - Room 402	4.6	ppb		
78000-403-S1	Sink in Science Lab/Classroom 403	2.0	ppb		
78000-403-S2	Sink in Science Lab/Classroom 403	2.7	ppb		
78000-403-S3	Sink in Science Lab/Classroom 403	2.6	ppb		
78000-403-S4	Sink in Science Lab/Classroom 403	3.1	ppb		
78000-403-S5	Sink in Science Lab/Classroom 403	4.0	ppb		
78000-403-S6	Sink in Science Lab/Classroom 403	2.3	ppb		
78000-425-S1	Sink in Science Lab/Classroom 425	25.2	ppb	1.4	ppb
78000-425-S2	Sink in Science Lab/Classroom 425	30.6	ppb	2.0	ppb
78000-425-S3	Sink in Science Lab/Classroom 425	41.9	ppb	3.5	ppb
78000-425-S4	Sink in Science Lab/Classroom 425	42.3	ppb	1.2	ppb
78000-425-S5	Sink in Science Lab/Classroom 425	19.9	ppb	0.2	ppb
78000-422-S1	Sink in Science Lab/Classroom 422	4.9	ppb		
78000-422-S2	Sink in Science Lab/Classroom 422	7.4	ppb		
78000-422-S3	Sink in Science Lab/Classroom 422	9.4	ppb		
78000-422-S4	Sink in Science Lab/Classroom 422	7.6	ppb		
78000-422-S5	Sink in Science Lab/Classroom 422	4.4	ppb		
78000-422-S6	Sink in Science Lab/Classroom 422	5.5	ppb		
78000-422-S7	Sink in Science Lab/Classroom 422	13.1	ppb		
78000-421-S1	Sink in Science Lab/Classroom 421	10.1	ppb		
78000-421-S2	Sink in Science Lab/Classroom 421	2.5	ppb		
78000-421-S3	Sink in Science Lab/Classroom 421	5.2	ppb		
78000-421-S4	Sink in Science Lab/Classroom 421	2.8	ppb		
78000-421-S5	Sink in Science Lab/Classroom 421	2.9	ppb		
78000-421-S6	Sink in Science Lab/Classroom 421	3.1	ppb		
78000-421-S7	Sink in Science Lab/Classroom 421	3.1	ppb		
78000-421-S8	Sink in Science Lab/Classroom 421	10.6	ppb		
78000-406-S	Sink in Science Prep Area - Room 406	1.6	ppb		
78000-405-S1	Sink in Science Lab/Classroom 405	2.8	ppb		
78000-405-S2	Sink in Science Lab/Classroom 405	2.4	ppb		
78000-405-S3	Sink in Science Lab/Classroom 405	1.9	ppb		
78000-405-S4	Sink in Science Lab/Classroom 405	1.6	ppb		
78000-405-S5	Sink in Science Lab/Classroom 405	3.8	ppb		
78000-405-S6	Sink in Science Lab/Classroom 405	3.7	ppb		
78000-407-S1	Sink in Science Lab/Classroom 407	3.2	ppb		
78000-407-S2	Sink in Science Lab/Classroom 407	4.6	ppb		
78000-407-S3	Sink in Science Lab/Classroom 407	5.4	ppb		
78000-407-S4	Sink in Science Lab/Classroom 407	6.5	ppb		
78000-407-S5	Sink in Science Lab/Classroom 407	4.7	ppb		
78000-407-S6	Sink in Science Lab/Classroom 407	3.1	ppb		
78000-408-S1	Sink in Science Lab/Classroom 408	5.2	ppb		
78000-408-S2	Sink in Science Lab/Classroom 408	2.3	ppb		
78000-408-S3	Sink in Science Lab/Classroom 408	2.5	ppb		
78000-408-S4	Sink in Science Lab/Classroom 408	5.1	ppb		
78000-408-S5	Sink in Science Lab/Classroom 408	1.9	ppb		
78000-408-S6	Sink in Science Lab/Classroom 408	2.4	ppb		
78000-408-S7	Sink in Science Lab/Classroom 408	2.9	ppb		
78000-411-S	Sink in Science Prep Area - Room 411	28.8	ppb	2.6	ppb
78000-413-S1	Sink in Science Lab/Classroom 413	4.0	ppb		
78000-413-S2	Sink in Science Lab/Classroom 413	5.7	ppb		
78000-413-S3	Sink in Science Lab/Classroom 413	6.6	ppb		
78000-413-S4	Sink in Science Lab/Classroom 413	13.7	ppb		
78000-413-S5	Sink in Science Lab/Classroom 413	6.7	ppb		
78000-413-S6	Sink in Science Lab/Classroom 413	6.2	ppb		
78000-413-S7	Sink in Science Lab/Classroom 413 (first sink on right from entrance to room)	47.9	ppb	1.4	ppb
78000-414-S1	Sink in Science Lab/Classroom 414	4.2	ppb		
78000-414-S2	Sink in Science Lab/Classroom 414	2.3	ppb		
78000-414-S3	Sink in Science Lab/Classroom 414	3.2	ppb		
78000-414-S4	Sink in Science Lab/Classroom 414	3.8	ppb		
78000-414-S5	Sink in Science Lab/Classroom 414	5.5	ppb		
78000-414-S6	Sink in Science Lab/Classroom 414	3.6	ppb		
78000-414-S7	Sink in Science Lab/Classroom 414	11.1	ppb		

78000-416-S	Sink in Science Prep Area - Room 416	10.1	ppb	
78000-417-S1	Sink in Science Lab/Classroom 417	5.2	ppb	
78000-417-S2	Sink in Science Lab/Classroom 417	4.9	ppb	
78000-418-S1	Sink in Science Lab/Classroom 418	8.6	ppb	
78000-418-S2	Sink in Science Lab/Classroom 418	1.6	ppb	
78000-709-S1	Sink in the Store (Room 709 by Student Dining Area) - Sink on the left of the two on the same wall	27.2	ppb	1.1 ppb
78000-709-S2	Sink in the Store (Room 709 by Student Dining Area) - Sink on the right of the two on the same wall	20.8	ppb	0.2 ppb
78000-709-S3	Sink in the Store (Room 709 by Student Dining Area) - Sink by itself nearest to the entrance door	14.9	ppb	
78000-705-DF	Drinking Fountain in Room 705 - Custodial Area	0.5	ppb	
78000-706-S	Sink in Room 706 - Custodial Area	2.6	ppb	
78000-1123-DF	Drinking Fountain in Locker Room 1123 -	1.2	ppb	
78000-1116-S	Sink in Training Room 1116	20.0	ppb	0.7 ppb
78000-1116-IM	Ice Machine in Training Room 1116	0.2	ppb	
78000-1115-WBFS	Water Bottle Filling Station in Hallway outside of Gym (across from Training Room)	0.3	ppb	
78000-1115-DF	Drinking Fountain in Hallway outside of Gym (across from Training Room)	0.3	ppb	
78000-1101-DF	Drinking Fountain in Locker Room 1101	14.5	ppb	
78000-714-S1	Food Service Sink - Hand Sink	1.1	ppb	
78000-714-S2	Food Service Sink - Hand Sink	3.6	ppb	
78000-714-S3	Food Service Sink - Sprayer	1.6	ppb	
78000-714-S4	Food Service Sink - Wash/Sanitize	0.5	ppb	
78000-714-S5	Food Service Sink - Sanitize/Rinse	2.5	ppb	
78000-714-S6	Food Service Sink - Hand Sink	0.6	ppb	
78000-714-S8	Food Service Sink - Sprayer	0.4	ppb	
78000-714-S9	Food Service Sink - Hand Sink	1.5	ppb	
78000-720-DFL	Drinking Fountain near Restrooms in Cafeteria/Left	0.3	ppb	
78000-720-DFR	Drinking Fountain near Restrooms in Cafeteria/Right	0.2	ppb	
78000-1001-S	Sink in Consumer Science Classroom 1001	6.5	ppb	
78000-1011-S1	Sink in Consumer Science Kitchen Classroom 1011	7.8	ppb	
78000-1011-S2	Sink in Consumer Science Kitchen Classroom 1011	3.4	ppb	
78000-1011-S3	Sink in Consumer Science Kitchen Classroom 1011	7.7	ppb	
78000-1011-S4	Sink in Consumer Science Kitchen Classroom 1011	8.1	ppb	
78000-1011-S5	Sink in Consumer Science Kitchen Classroom 1011	6.6	ppb	
78000-1011-S6	Sink in Consumer Science Kitchen Classroom 1011	6.9	ppb	
78000-1011-S7	Sink in Consumer Science Kitchen Classroom 1011	10.0	ppb	
78000-1031H-DF	Drinking Fountain near Cafeteria in Hallway leading to Art Room 1046	< 0.1*	ppb	
78000-1015-S	Sink in CCTV Lab 1015	1.5	ppb	
78000-1016-S1	Sink in Technology Lab 1016	212.6	ppb	0.8 ppb
78000-1024-DF	Drinking Fountain in Instrument/Band Room 1024	0.4	ppb	
78000-1037-S	Sink in Technology Lab 1037	14.2	ppb	
78000-1037-SWB	Sink with Bubbler in Technology Lab 1037	62.2	ppb	7.7 ppb
78000-1035-DF	Drinking Fountain in Tech Ed Lab 1035	0.6	ppb	
78000-1043-DF	Drinking Fountain in Tech Ed Lab 1043	1.3	ppb	
78000-1046-S1	Sink in Art Room 1046	8.9	ppb	
78000-1046-S2	Sink in Art Room 1046	2.1	ppb	
78000-1056-S1	Sink in Art Room 1056	1.1	ppb	
78000-1056-S2	Sink in Art Room 1056	0.7	ppb	
78000-1056-S3	Sink in Art Room 1056	9.3	ppb	
78000-1052-S1	Sink in Art Room 1052	1.8	ppb	
78000-1052-S2	Sink in Art Room 1052	1.7	ppb	
78000-807-SWB	Sink with Bubbler just outside practice rooms by Vocal Classroom 807	< 0.1*	ppb	
78000-807-S	Sink just outside practice rooms by Vocal Classroom 807	12.9	ppb	
78000-815-S	Sink in Drama Storage Area - Room 815	7.7	ppb	
78000-SSWR-S	Sink in Social Studies Workroom - 2nd Floor	1.2	ppb	
78000-FLWR-S	Sink in World Language Workroom - 2nd Floor	3.4	ppb	
78000-310H-DFL	Drinking Fountain near Social Studies/World Language Areas on 2nd Floor/Left	0.3	ppb	
78000-310H-DFR	Drinking Fountain near Social Studies/World Language Areas on 2nd Floor/Right	0.3	ppb	

* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.

** Resampling results after elevated fixtures were removed and replaced.