

## Prospect Valley Elementary School - Sampled 7/22/16

CustomerSampleNumber	Description	Lead Result	Units
34000-040-S	Sink in Clinic	0.7	ppb
34000-007-S	Sink in Classroom 007	2.6	ppb
34000-007-SWB	Sink with Bubbler in Classroom 007	0.7	ppb
34000-007-DF	Drinking Fountain in Classroom 007	1.1	ppb
34000-008-S	Sink in Classroom 008	2.6	ppb
34000-008-SWB	Sink with Bubbler in Classroom 008	2.5	ppb
34000-010-S	Sink in Classroom 010	2.1	ppb
34000-010-SWB	Sink with Bubbler in Classroom 010	2.4	ppb
34000-010-DF	Drinking Fountain in Classroom 010	2.0	ppb
34000-011-S	Sink in Kindergarten Classroom 011	2.1	ppb
34000-011-SWB	Sink with Bubbler in Kindergarten Classroom 011	1.6	ppb
34000-014-S	Sink in Library Work Room	5.6	ppb
34000-014-SWB	Sink with Bubbler in Library Work Room	8.8	ppb
34000-26D-S1	Art Room Sink	0.8	ppb
34000-26D-S2	Art Room Sink	2.2	ppb
34000-26A-S	Sink in Teacher's Lounge	2.1	ppb
34000-26A-SWB	Sink with Bubbler in Teacher's Lounge	0.9	ppb
34000-017-S	Sink in Classroom 017	352.8	ppb
34000-017-SWB	Sink with Bubbler in Classroom 017	2.5	ppb
34000-018-S	Sink in Classroom 018	5.5	ppb
34000-018-SWB	Sink with Bubbler in Classroom 018	3.3	ppb
34000-019-S	Sink in Classroom 019	4.8	ppb
34000-019-SWB	Sink with Bubbler in Classroom 019	2.6	ppb
34000-021-S	Sink in Classroom 021	7.8	ppb
34000-021-SWB	Sink with Bubbler in Classroom 021	0.5	ppb
34000-023-SWB	Sink with Bubbler in Classroom 023	3.2	ppb
34000-023-S	Sink in Classroom 023	4.9	ppb
34000-022-S	Sink in Classroom 022	4.2	ppb
34000-022-SWB	Sink with Bubbler in Classroom 022	0.9	ppb
34000-047H-DFL	Hallway Drinking Fountain across from Main Office/Left	<0.1 *	ppb
34000-047H-DFR	Hallway Drinking Fountain across from Main Office/Right	<0.1 *	ppb
34000-047H-WBFS	Hallway Water Bottle Filling Station across from Main Office	<0.1 *	ppb
34000-101-S	Sink in Classroom 101	2.5	ppb
34000-101-SWB	Sink with Bubbler in Classroom 101	<0.1 *	ppb
34000-102-S	Sink in Classroom 102	5.6	ppb
34000-102-SWB	Sink with Bubbler in Classroom 102	<0.1 *	ppb
34000-099H-DFL	Hallway Drinking Fountain near Computer Area/Left	1.3	ppb
34000-099H-DFR	Hallway Drinking Fountain near Computer Area/Right	0.8	ppb
34000-104-S	Sink in Classroom 104	5.6	ppb
34000-104-SWB	Sink with Bubbler in Classroom 104	0.1	ppb
34000-103-S	Sink in Classroom 103	5.5	ppb
34000-103-SWB	Sink with Bubbler in Classroom 103	<0.1 *	ppb
34000-054-S1	Food Service Sink-Food Prep	13.7	ppb
34000-054-S2	Food Service Sink-Food Prep	282.2	ppb
34000-054-S3	Food Service Sink-Hand Sink	12.6	ppb
34000-054-S4	Food Service Sink-Wash/Rinse	4.4	ppb
34000-054-S5	Food Service Sink-Sprayer	3.1	ppb

\* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.