

Ralston Valley High School - Sampled 11/3/16			
CustomerSampleNumber	Description	Lead Result	Unit
78200-B110-S1	Food Service Sink-Hand Sink	3.6	ppb
78200-B110-S2	Food Service Sink-Hand Sink	1.3	ppb
78200-B110-S3	Food Service Sink-Sprayer	0.5	ppb
78200-B110-S4	Food Service Sink-Sanitize/Rinse	0.3	ppb
78200-B110-S5	Food Service Sink-Rinse/Wash	1.1	ppb
78200-B110-S6	Food Service Sink-Hand Sink	1.7	ppb
78200-B110-S7	Food Service Sink-Food Prep	2.4	ppb
78200-B110-S8	Food Service Sink-Food Prep Sprayer	0.8	ppb
78200-B110-IM	Ice Machine in Food Service	<0.1 *	ppb
78200-A131H-DFL	Hallway Drinking Fountain across from Locker Rooms/Left	0.1	ppb
78200-A131H-DFR	Hallway Drinking Fountain across from Locker Rooms/Right	0.3	ppb
78200-A133-IM	Ice Machine in Training Room A133	0.3	ppb
78200-A133-S	Sink in Training Room A133	0.3	ppb
78200-A135-DF	Drinking Fountain in Weight Room A135	<0.1 *	ppb
78200-A101-DFL	Drinking Fountain in Gym/Left	0.1	ppb
78200-A101-DFR	Drinking Fountain in Gym/Right	0.1	ppb
78200-C102H-WBFS	Hallway Water Bottle Filling Station across from Cafeteria	<0.1 *	ppb
78200-C102H-DFL	Hallway Drinking Fountain across from Cafeteria/Left	<0.1 *	ppb
78200-C102H-DFR	Hallway Drinking Fountain across from Cafeteria/Right	<0.1 *	ppb
78200-C110-S	Sink in Store	<0.1 *	ppb
78200-C125-S	Sink in Office C125 near Computer Rooms	1.2	ppb
78200-D105H-DFL	Hallway Drinking Fountain across from Classroom S1111/Left	0.3	ppb
78200-D105H-DFR	Hallway Drinking Fountain across from Classroom S1111/Right	0.5	ppb
78200-G123-S	Sink in Office G123	0.5	ppb
78200-G123-IM	Ice Machine in Office G123	4.2	ppb
78200-G104-S2	Sink in Science Prep Room G104	1.8	ppb
78200-D115-S	Sink in Science Prep Room D115	0.1	ppb
78200-G108H-DFL	Hallway Drinking Fountain near Labs S1115 and S1116/Left	0.7	ppb
78200-G108H-DFR	Hallway Drinking Fountain near Labs S1115 and S1116/Right	0.6	ppb
78200-S1116-S4	Sink in Laboratory S1116	1.9	ppb
78200-S1118-S1	Sink in Laboratory S1118	0.7	ppb
78200-E100H-DFL	Hallway Drinking Fountain across from Lab S1119/Left	0.5	ppb
78200-E100H-DFR	Hallway Drinking Fountain across from Lab S1119/Right	0.2	ppb
78200-D114-S	Sink in Office D114	0.2	ppb
78200-D114-IM	Ice Machine in Office D114	0.2	ppb
78200-E118-S	Sink in Office E118 across from Classroom M1122	0.5	ppb
78200-E118-IM	Ice Machine in Office E118 across from Classroom M1122	1.1	ppb
78200-C137-S	Sink in Storage Room C137	0.2	ppb
78200-C146-S	Sink in Office Work Room C146	<0.1 *	ppb
78200-C146-IM	Ice Machine in Office Work Room C146	2.0	ppb
78200-C144-S	Sink in Clinic	0.3	ppb
78200-B200-S	Sink in Teacher's Lounge B200	0.6	ppb
78200-A200-DFL	Drinking Fountain in Weight Room A200/Left	0.2	ppb
78200-A200-DFR	Drinking Fountain in Weight Room A200/Right	<0.1 *	ppb

78200-C201H-DF	Hallway Drinking Fountain near Auditorium	<0.1 *	ppb
78200-C241H-DF	Hallway Drinking Fountain near Auditorium	<0.1 *	ppb
78200-C224-S	Sink in Instrument/Band Room	1.0	ppb
78200-C224-DF	Drinking Fountain in Instrument/Band Room	0.3	ppb
78200-C231-DF	Drinking Fountain in Vocal Music Room	0.7	ppb
78200-G2210-S1	Sink in Art Room 2210	0.1	ppb
78200-F210-S	Sink in Office F210	1.3	ppb
78200-F210-IM	Ice Machine in Office F210	0.3	ppb
78200-D200H-DFL	Hallway Drinking Fountain across from Art Room G2211/Left	<0.1 *	ppb
78200-D200H-DFR	Hallway Drinking Fountain across from Art Room G2211/Right	0.2	ppb
78200-E2253-S	Sink in Classroom E2253	6.3	ppb
78200-G2254-S	Sink in Classroom G2254	7.7	ppb
78200-G212H-DFL	Hallway Drinking Fountain outside of Classroom E2251/Left	0.8	ppb
78200-G212H-DFR	Hallway Drinking Fountain outside of Classroom E2251/Right	2.7	ppb
78200-G223-S	Sink in Office G223	0.5	ppb
78200-G223-IM	Ice Machine in Office G223	0.7	ppb
78200-G225H-DFL	Hallway Drinking Fountain outside of Classroom E2241/Left	0.5	ppb
78200-G225H-DFR	Hallway Drinking Fountain outside of Classroom E2241/Right	0.8	ppb
78200-D214-S	Sink in Library Work Room	0.3	ppb
78200-G200H-DFL	Hallway Drinking Fountain outside of Library/Left	<0.1 *	ppb
78200-G200H-DFR	Hallway Drinking Fountain outside of Library/Right	0.1	ppb
78200-E216-S	Sink in Office E216	0.4	ppb
78200-E216-IM	Ice Machine in Office E216	3.9	ppb
78200-R2205-S1	Sink in Kitchen Classroom R2205	0.4	ppb
78200-R2205-S2	Sink in Kitchen Classroom R2205	0.4	ppb
78200-R2205-S3	Sink in Kitchen Classroom R2205	0.4	ppb
78200-R2205-S4	Sink in Kitchen Classroom R2205	0.4	ppb
78200-R2205-S5	Sink in Kitchen Classroom R2205	0.2	ppb
78200-R2205-S6	Sink in Kitchen Classroom R2205	0.3	ppb
78200-R2205-S7	Sink in Kitchen Classroom R2205	0.2	ppb
78200-W2229-S	Sink in Classroom W2229	0.3	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.			