

Semper Elementary School - Sampled 10/13/16			
CustomerSampleNumber	Description	Lead Result	Unit
40100-C03H-DF	Hallway Drinking Fountain outside of Gym	<0.1 *	ppb
40100-66-S	Sink in Clinic	1.2	ppb
40100-68-S	Sink in Teacher's Lounge	0.3	ppb
40100-65-S	Sink in Planning Room 65	10.2	ppb
40100-74-S	Sink in Instrument/Band Room	0.4	ppb
40100-75-DF	Drinking Fountain in Cafeteria	0.1	ppb
40100-76-S1	Food Service Sink-Hand Sink	5.0	ppb
40100-76-S2	Food Service Sink-Hand Sink	3.7	ppb
40100-76-S3	Food Service Sink-Wash/Rinse	5.3	ppb
40100-76-S4	Food Service Sink-Sprayer	0.7	ppb
40100-76-S5	Food Service Sink-Rinse/Sanitize	5.1	ppb
40100-76-S6	Food Service Sink-Hand Sink	9.2	ppb
40100-76-S7	Food Service Sink-Sprayer	20.8	ppb
40100-76-S10	Food Service Sink-Food Prep	3.9	ppb
40100-C11H-DF	Hallway Drinking Fountain across from Kindergarten Classroom 36	0.1	ppb
40100-36-S	Sink in Kindergarten Classroom 36	1.0	ppb
40100-36-SWB	Sink with Bubbler in Kindergarten Classroom 36	0.3	ppb
40100-35-S	Sink in Kindergarten Classroom 35	0.6	ppb
40100-35-SWB	Sink with Bubbler in Kindergarten Classroom 35	1.2	ppb
40100-34-S	Sink in Classroom 34	0.9	ppb
40100-34-SWB	Sink with Bubbler in Classroom 34	0.3	ppb
40100-33-S	Sink in Classroom 33	0.6	ppb
40100-33-SWB	Sink with Bubbler in Classroom 33	1.6	ppb
40100-32-S	Sink in Classroom 32	6.6	ppb
40100-32-SWB	Sink with Bubbler in Classroom 32	0.8	ppb
40100-31-S	Sink in Classroom 31	0.8	ppb
40100-31-SWB	Sink with Bubbler in Classroom 31	0.4	ppb
40100-30-S	Sink in Classroom 30	0.5	ppb
40100-30-SWB	Sink with Bubbler in Classroom 30	0.1	ppb
40100-29-S	Sink in Classroom 29	0.7	ppb
40100-29-SWB	Sink with Bubbler in Classroom 29	1.0	ppb
40100-C13H-DF	Hallway Drinking Fountain across from Classroom 29	<0.1 *	ppb
40100-50-S	Sink in Library Workroom	2.3	ppb
40100-47-S1	Sink in Art Room 47	1.3	ppb
40100-47-S2	Sink in Art Room 47	0.9	ppb
40100-47-S3	Sink in Art Room 47	0.7	ppb
40100-47-S4	Sink in Art Room 47	1.1	ppb
40100-C17H-DF	Hallway Drinking Fountain across from Classroom 22	<0.1 *	ppb
40100-22-S	Sink in Classroom 22	0.7	ppb
40100-22-SWB	Sink with Bubbler in Classroom 22	0.3	ppb
40100-21-S	Sink in Classroom 21	3.3	ppb
40100-21-SWB	Sink with Bubbler in Classroom 21	8.2	ppb
40100-19-S	Sink in Classroom 19	0.3	ppb
40100-19-SWB	Sink with Bubbler in Classroom 19	0.1	ppb
40100-18-S	Sink in Classroom 18	0.8	ppb
40100-18-SWB	Sink with Bubbler in Classroom 18	0.1	ppb
40100-17-S	Sink in Classroom 17	1.4	ppb

40100-17-SWB	Sink with Bubbler in Classroom 17	0.1	ppb
40100-16-S	Sink in Classroom 16	0.4	ppb
40100-16-SWB	Sink with Bubbler in Classroom 16	1.1	ppb
40100-15-S	Sink in Classroom 15	0.4	ppb
40100-15-SWB	Sink with Bubbler in Classroom 15	0.2	ppb
40100-C24H-DF	Hallway Drinking Fountain across from Classroom 08	<0.1 *	ppb
40100-08-S	Sink in Classroom 08	0.4	ppb
40100-08-SWB	Sink with Bubbler in Classroom 08	1.2	ppb
40100-07-S	Sink in Classroom 07	0.6	ppb
40100-07-SWB	Sink with Bubbler in Classroom 07	0.7	ppb
40100-06-S	Sink in Classroom 06	1.2	ppb
40100-06-SWB	Sink with Bubbler in Classroom 06	0.3	ppb
40100-05-S	Sink in Classroom 05	3.2	ppb
40100-05-SWB	Sink with Bubbler in Classroom 05	0.7	ppb
40100-04-S	Sink in Classroom 04	1.0	ppb
40100-04-SWB	Sink with Bubbler in Classroom 04	1.9	ppb
40100-14-S	Sink in Planning Room 14	5.8	ppb
40100-03-S	Sink in Classroom 03	0.8	ppb
40100-03-SWB	Sink with Bubbler in Classroom 03	0.3	ppb
40100-02-S	Sink in Classroom 02	0.4	ppb
40100-02-SWB	Sink with Bubbler in Classroom 02	0.5	ppb
40100-C22H-DF	Hallway Drinking Fountain across from Classroom 01	<0.1 *	ppb
40100-01-S	Sink in Classroom 01	0.6	ppb
40100-28-S	Sink in Planning Room 28	8.5	ppb
40100-42-S	Sink in Planning Room 42	7.1	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.			