

Shaffer Elementary School - Sampled 10/20/16			
CustomerSampleNumber	Description	Lead Result	Unit
40300-B20-S	Sink in Clinic	0.4	ppb
40300-D20-S	Sink in Kindergarten Classroom D20	0.2	ppb
40300-D20-SWB	Sink with Bubbler in Kindergarten Classroom D20	0.3	ppb
40300-D19-S	Sink in Classroom D19	<0.1 *	ppb
40300-D19-SWB	Sink with Bubbler in Classroom D19	0.2	ppb
40300-D18-S	Sink in Classroom D18	0.1	ppb
40300-D18-SWB	Sink with Bubbler in Classroom D18	0.2	ppb
40300-D17-S	Sink in Classroom D17	0.3	ppb
40300-D17-SWB	Sink with Bubbler in Classroom D17	0.4	ppb
40300-D01-S	Sink in Classroom D01	0.8	ppb
40300-D01-SWB	Sink with Bubbler in Classroom D01	0.3	ppb
40300-D02-S	Sink in Classroom D02	0.3	ppb
40300-D02-SWB	Sink with Bubbler in Classroom D02	0.3	ppb
40300-D03-S	Sink in Classroom D03	0.4	ppb
40300-D03-SWB	Sink with Bubbler in Classroom D03	1.6	ppb
40300-D04-S	Sink in Classroom D04	0.4	ppb
40300-D04-SWB	Sink with Bubbler in Classroom D04	0.1	ppb
40300-D09H-DF	Hallway Drinking Fountain outside of Planning Room D21	0.4	ppb
40300-A20-S	Sink in Kindergarten Classroom A20	0.3	ppb
40300-A20-SWB	Sink with Bubbler in Kindergarten Classroom A20	0.3	ppb
40300-A19-S	Sink in Classroom A19	0.3	ppb
40300-A19-SWB	Sink with Bubbler in Classroom A19	0.1	ppb
40300-A18-S	Sink in Classroom A18	0.7	ppb
40300-A18-SWB	Sink with Bubbler in Classroom A18	0.3	ppb
40300-A17-S	Sink in Classroom A17	0.3	ppb
40300-A17-SWB	Sink with Bubbler in Classroom A17	0.5	ppb
40300-A01-S	Sink in Classroom A01	0.2	ppb
40300-A01-SWB	Sink with Bubbler in Classroom A01	0.3	ppb
40300-A02-S	Sink in Classroom A02	0.3	ppb
40300-A02-SWB	Sink with Bubbler in Classroom A02	0.4	ppb
40300-A03-S	Sink in Classroom A03	0.6	ppb
40300-A03-SWB	Sink with Bubbler in Classroom A03	0.4	ppb
40300-A04-S	Sink in Classroom A04	0.2	ppb
40300-A04-SWB	Sink with Bubbler in Classroom A04	0.2	ppb
40300-A09H-DF	Hallway Drinking Fountain outside of Planning Room A21	0.2	ppb
40300-E20-S	Sink in Classroom E20	0.2	ppb
40300-E20-SWB	Sink with Bubbler in Classroom E20	0.1	ppb
40300-E19-S	Sink in Classroom E19	1.3	ppb
40300-E19-SWB	Sink with Bubbler in Classroom E19	0.4	ppb
40300-E18-S	Sink in Classroom E18	<0.1 *	ppb
40300-E18-SWB	Sink with Bubbler in Classroom E18	0.2	ppb
40300-E17-S	Sink in Classroom E17	0.1	ppb
40300-E17-SWB	Sink with Bubbler in Classroom E17	0.4	ppb

40300-E01-S	Sink in Classroom E01	0.1	ppb
40300-E01-SWB	Sink with Bubbler in Classroom E01	0.2	ppb
40300-E02-S	Sink in Classroom E02	0.2	ppb
40300-E02-SWB	Sink with Bubbler in Classroom E02	0.3	ppb
40300-E03-S	Sink in Classroom E03	0.9	ppb
40300-E03-SWB	Sink with Bubbler in Classroom E03	0.5	ppb
40300-E04-S	Sink in Classroom E04	0.6	ppb
40300-E04-SWB	Sink with Bubbler in Classroom E04	0.4	ppb
40300-E09H-DF	Hallway Drinking Fountain outside of Planning Room E21	0.5	ppb
40300-B13-S1	Sink in Art Room B13	0.7	ppb
40300-B13-S2	Sink in Art Room B13	0.4	ppb
40300-C03-S	Sink in Music Room C03	0.5	ppb
40300-C03-SWB	Sink with Bubbler in Music Room C03	1.4	ppb
40300-C24-S1	Food Service Sink-Food Warmer	3.0	ppb
40300-C24-S2	Food Service Sink-Food Warmer	0.6	ppb
40300-C24-S3	Food Service Sink-Hand Sink	<0.1 *	ppb
40300-C25-S	Food Service Sink-Sprayer	0.6	ppb
40300-C26-S1	Food Service Sink-Wash/Rinse	0.4	ppb
40300-C26-S2	Food Service Sink-Rinse/Sanitize	0.5	ppb
40300-C26-S3	Food Service Sink-Hand Sink	0.2	ppb
40300-C26-S4	Food Service Sink-Food Prep	0.7	ppb
40300-C14-DFL	Drinking Fountain across from Gym/Left	0.3	ppb
40300-C14-DFR	Drinking Fountain across from Gym/Right	0.4	ppb
40300-C13-S	Sink in Teacher's Lounge	0.7	ppb
40300-C13-WC	Water Cooler in Teacher's Lounge	<0.1 *	ppb
40300-R1-132-DF	Drinking Fountain in TEMP R1-132	12.0	ppb
40300-REC-062-DF	Drinking Fountain in TEMP REC-062	0.9	ppb
40300-RE-034-DF	Drinking Fountain in TEMP RE-034	1.9	ppb
40300-R1-164-DF	Drinking Fountain in TEMP R1-164	5.2	ppb
40300-R1-103-DF	Drinking Fountain in TEMP R1-130	22.2	ppb
40300-REC-072-DF	Drinking Fountain in TEMP REC-072	1.7	ppb

* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.