

Sheridan Green Elementary School - Sampled 7/7/16			
CustomerSampleNumber	Description	Lead Result	Units
21000-112-S	Sink in the Planning Room near Clinic	0.8	ppb
21000-113-S	Sink in the Clinic	1.6	ppb
21000-128-S	Sink in the Teacher's Lounge	1.0	ppb
21000-120-S1	Art Room Sink	6.9	ppb
21000-120-S2	Art Room Sink	9.4	ppb
21000-120-S3	Art Room Sink	3.3	ppb
21000-120-S4	Art Room Sink	10.0	ppb
21000-211-S2	Food Service Sink-Rinse/Wash	6.6	ppb
21000-211-S3	Food Service Sink-Hand Wash	3.1	ppb
21000-211-S1	Food Service Sink-Rinse/Wash	4.8	ppb
21000-214H-DF	Hallway Drinking Fountain near Music Room	0.3	ppb
21000-223H-DF1	Hallway Drinking Fountain near Classroom C6	3.7	ppb
21000-228-S	Sink in Hallway near Classroom C7	2.1	ppb
21000-223H-DF2	Hallway Drinking Fountain near Classroom C2	5.6	ppb
21000-166H-DF1	Hallway Drinking Fountain near Classroom B6	0.3	ppb
21000-161-S	Sink in Hallway near Classroom B7	0.5	ppb
21000-166H-DF2	Hallway Drinking Fountain near Classroom B2	7.0	ppb
21000-142H-DF1	Hallway Drinking Fountain near Classroom A6	0.5	ppb
21000-137-S	Sink in Hallway near Classroom A7	0.7	ppb
21000-142H-DF2	Hallway Drinking Fountain near Classroom A2	1.1	ppb
21000-227-S	Sink in Library Workroom	7.0	ppb
21000-132H-DF	Hallway Drinking Fountain near Classroom A1	0.1	ppb
21000-002-S	Sink in Kindergarten Classroom 002	2.0	ppb
21000-002-SWB	Sink with Bubbler in Kindergarten Classroom 002	7.5	ppb
21000-001-S	Sink in Kindergarten Classroom 001	1.6	ppb
21000-001-SWB	Sink with Bubbler in Kindergarten Classroom 001	1.5	ppb