

Slater Elementary School - Sampled 6/3/16

CustomerSampleNumber	Description	Lead Result	Units
41000-001-DF	Kindergarten drinking fountain	25.7	ppb
41000-001-S	Kindergarten sink	2.4	ppb
41000-005H-DF	Hallway drinking fountain	27.8	ppb
41000-005-S	Conf Room sink	5.0	ppb
41000-007-S	Teacher's lounge sink	0.6	ppb
41000-22-S1	Food Service Prep Sink	6.6	ppb
41000-22-S2	Food Service Rinse Sink	3.7	ppb
41000-22-S3	Food Service Sanitize Sink	1.8	ppb
41000-22-S4	Food Service Hand Sink	15.4	ppb
41000-23-DF	Cafeteria drinking fountain	31.9	ppb
41000-25-S	Clinic sink	0.4	ppb
41000-37H-DFL	B-wing Hallway drinking fountain L	9.0	ppb
41000-37H-DFR	B-wing Hallway drinking fountain R	2.8	ppb
41000-41-DF	Classroom 41/A1 drinking fountain	6.6	ppb
41000-41-S	Classroom 41/A1	2.8	ppb
41000-43-DF	Classroom 43/A2 drinking fountain	12.9	ppb
41000-43-S	Classroom 43/A2 sink	7.5	ppb
41000-46-DF	Classroom 46/B1 drinking fountain	13.3	ppb
41000-46-S	Classroom 46/B1 sink	12.5	ppb
41000-47-DF	Classroom 47/B2 drinking fountain	14.7	ppb
41000-47-S	Classroom 47/B2 sink	110.8	ppb
41000-49-DF	Classroom 49/A3 drinking fountain	9.1	ppb
41000-49-S	Classroom 49/A3 sink	26.2	ppb
41000-52-DF	Classroom 52/B3 drinking fountain	5.7	ppb
41000-52-S	Classroom 52/B3 sink	12.0	ppb
41000-53-DF	Classroom 53/A4 drinking fountain	11.4	ppb
41000-53-S	Classroom 53/A4 sink	10.7	ppb
41000-56-DF	Classroom 56/B4	3.8	ppb
41000-56-S	Classroom 56/B4	5.0	ppb
41000-61A-S	Library Workroom sink	105.9	ppb
41000-69-S2	Classroom 69/Art	5.2	ppb
41000-69-SI	Classroom 69/Art	8.1	ppb
41000-76H-DFL	C-Wing Hallway drinking fountain L	19.1	ppb
41000-76H-DFR	C-Wing Hallway drinking fountain R	4.3	ppb
41000-82H-DF	D-Wing Hallway drinking fountain	1.4	ppb
41000-85-DF	Classroom 85/C1 drinking fountain	5.3	ppb
41000-85-S	Classroom 85/C1 sink	8.3	ppb
41000-86-DF	Classroom 86/C2 drinking fountain	4.6	ppb
41000-86-S	Classroom 86/C2 sink	7.5	ppb
41000-91-DF	Classroom 91/C3 drinking fountain	6.4	ppb
41000-91-S	Classroom 91/C3 sink	6.0	ppb
41000-92-DF	Classroom 92/C drinking fountain	6.6	ppb
41000-92-S	Classroom 92/C4 sink	13.8	ppb
41000-93-S	Classroom 93/D1	3.7	ppb
41000-94-S	Classroom 94/D2	2.1	ppb
41000-95-S	Classroom 95/D3	3.1	ppb
41000-96-S	Classroom 96/D4	1.4	ppb
41000-R1-084-DF	Temp R1-084 drinking fountain	1.6	ppb
41000-RE-011-DF	Temp RE-011 drinking fountain	4.2	ppb
41000-RE-048-DF	Temp RE-048 drinking fountain	0.7	ppb
41000-REC-132-DF	Temp REC-132 drinking fountain	5.7	ppb