

Sobesky Academy - Sampled 11/4/16				Resampled** 1/25/17	
CustomerSampleNumber	Description	Lead Result	Unit	Lead Result	Unit
85100-181-S	Sink in Music Room 181	2.1	ppb		
85100-190-S1	Food Service Sink-Sprayer	7.3	ppb		
85100-190-S2	Food Service Sink-Food Prep	1.6	ppb		
85100-190-S3	Food Service Sink-Hand Sink	1.5	ppb		
85100-195-S1	Food Service Sink-Rinse/Wash	1.9	ppb		
85100-195-S2	Food Service Sink-Wash/Sanitize	16.0	ppb	7.1	ppb
85100-195-S3	Food Service Sink-Sprayer	12.2	ppb		
85100-174H-DF	Hallway Drinking Fountain outside of Cafeteria	<0.1 *	ppb		
85100-130-S	Sink in Weight Room 130	11.1	ppb		
85100-152H-DF	Hallway Sink outside of Weight Room 130	<0.1 *	ppb		
85100-129-S	Sink in Classroom 129	8.8	ppb		
85100-128-S	Sink in Classroom 128	10.9	ppb		
85100-127-S	Sink in Classroom 127	10.2	ppb		
85100-126-S	Sink in Classroom 126	17.7	ppb	6.6	ppb
85100-125-S	Sink in Classroom 125	23.2	ppb	2.4	ppb
85100-132H-DF	Hallway Drinking Fountain across from Classroom 125	<0.1 *	ppb		
85100-124-S	Sink in Classroom 124	7.7	ppb		
85100-123-S	Sink in Classroom 123	4.4	ppb		
85100-122-S	Sink in Kindergarten Classroom 122	6.2	ppb		
85100-121-S	Sink in Classroom 121	14.1	ppb		
85100-120-S	Sink in Kindergarten Classroom 120	0.5	ppb		
85100-114-S1	Sink in Art Room 114	5.5	ppb		
85100-114-S2	Sink in Art Room 114	2.9	ppb		
85100-107-S	Sink in Teacher's Lounge	0.6	ppb		
85100-167-S	Sink in Library Work Room	5.0	ppb		
85100-218H-DF	Hallway Drinking Fountain across from Classroom 229	<0.1 *	ppb		
85100-229-S	Sink in Classroom 229	7.3	ppb		
85100-228-S	Sink in Classroom 228	6.8	ppb		
85100-227-S	Sink in Classroom 227	8.3	ppb		
85100-226-S	Sink in Classroom 226	9.6	ppb		
85100-225-S	Sink in Classroom 225	12.9	ppb		
85100-224-S	Sink in Classroom 224	7.7	ppb		
85100-207H-DF	Hallway Drinking Fountain across from Classroom 224	<0.1 *	ppb		
85100-223-S	Sink in Classroom 223	8.8	ppb		
85100-222-S	Sink in Classroom 222	3.0	ppb		
85100-221-S	Sink in Classroom 221	8.2	ppb		
85100-220-S	Sink in Classroom 220	14.5	ppb		
85100-108-S	Sink in Clinic	1.9	ppb		
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.					
** Resampling results after elevated fixtures were repaired, or removed and replaced.					