

South Lakewood Elementary School - Sampled 10/26/16			
CustomerSampleNumber	Description	Lead Result	Unit
43000-101A-S	Sink in Classroom 101A	15.4	ppb
43000-102-S	Sink in Classroom 102	2.3	ppb
43000-103-S	Sink in Classroom 103	2.0	ppb
43000-138H-DF	Hallway Drinking Fountain across from Classroom 103	<0.1 *	ppb
43000-104-S	Sink in Classroom 104	1.8	ppb
43000-105-S	Sink in Classroom 105	1.5	ppb
43000-106-S	Sink in Classroom 106	4.7	ppb
43000-170-S	Sink in Music Room 170	4.0	ppb
43000-167-DF	Drinking Fountain in Cafeteria	<0.1 *	ppb
43000-166-S1	Food Service Sink-Wash/Rinse	1.0	ppb
43000-166-S2	Food Service Sink-Rinse/Sanitize	0.6	ppb
43000-166-S3	Food Service Sink-Hand Sink	1.4	ppb
43000-166-S4	Food Service Sink-Food Prep	1.3	ppb
43000-166E-S1	Food Service Sink-Sprayer	7.7	ppb
43000-166E-S2	Food Service Sink-Hand Sink	0.2	ppb
43000-125CH-DF	Hallway Drinking Fountain across from Art Room 156	<0.1 *	ppb
43000-156-S1	Art Room Sink	0.3	ppb
43000-156-S2	Art Room Sink	1.6	ppb
43000-164-S	Sink in Library Work Room	1.0	ppb
43000-112-S	Sink in Classroom 112	1.8	ppb
43000-111-S	Sink in Classroom 111	1.3	ppb
43000-110-S	Sink in Classroom 110	1.9	ppb
43000-116H-DF	Hallway Drinking Fountain outside of Kindergarten Classroom 109	<0.1 *	ppb
43000-109-S	Sink in Kindergarten Classroom 109	1.3	ppb
43000-108-S	Sink in Kindergarten Classroom 108	1.0	ppb
43000-107-S	Sink in Classroom 107	2.2	ppb
43000-121-S	Sink in Teacher's Lounge	<0.1 *	ppb
43000-125AH-DF	Hallway Drinking Fountain outside of Main Office Area	<0.1 *	ppb
43000-122-S	Sink in Clinic	1.4	ppb
43000-201-S	Sink in Classroom 201	1.8	ppb
43000-202-S	Sink in Classroom 202	2.2	ppb
43000-203-S	Sink in Classroom 203	0.9	ppb
43000-220H-DF	Hallway Drinking Fountain outside of Classrooms 203 and 204	<0.1 *	ppb
43000-204-S	Sink in Classroom 204	0.5	ppb
43000-205-S	Sink in Classroom 205	2.2	ppb
43000-206-S	Sink in Classroom 206	3.9	ppb
43000-225XH-DF	Hallway Drinking Fountain across from 2nd Floor Elevator	<0.1 *	ppb
43000-212-S	Sink in Classroom 212	2.2	ppb
43000-211-S	Sink in Classroom 211	1.6	ppb
43000-210-S	Sink in Classroom 210	0.7	ppb
43000-233H-DF	Hallway Drinking Fountain outside of Classrooms 209 and 210	<0.1 *	ppb
43000-209-S	Sink in Classroom 209	0.3	ppb
43000-208-S	Sink in Classroom 208	1.6	ppb
43000-207-S	Sink in Classroom 207	1.1	ppb

* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.