

Stott Elementary School - Sampled 7/15/16			
CustomerSampleNumber	Description	Lead Result	Units
38200-134-S	Sink in Kindergarten Classroom 134	0.8	ppb
38200-134-SWB	Sink with Bubbler in Kindergarten Classroom 134	0.8	ppb
38200-130-SWB	Sink with Bubbler in Kindergarten Classroom 130	0.9	ppb
38200-130-S	Sink in Kindergarten Classroom 130	1.1	ppb
38200-122-SWB	Sink with Bubbler in Clinic	1.9	ppb
38200-122-S	Sink in Clinic	3.2	ppb
38200-120H-DFL	Hallway Drinking Fountain across from Gym/Left	0.3	ppb
38200-120H-DFR	Hallway Drinking Fountain across from Gym/Right	0.8	ppb
38200-105H-DF	Hallway Drinking Fountain across from Book Room	1.0	ppb
38200-100-DF	Drinking Fountain in Cafeteria	0.6	ppb
38200-153-S1	Food Service Sink-Food Prep	59.6	ppb
38200-153-S2	Food Service Sink-Food Prep	22.0	ppb
38200-153-S3	Food Service Sink-Wash/Rinse	15.6	ppb
38200-153-S4	Food Service Sink-Wash/Rinse	17.0	ppb
38200-153-S5	Food Service Sink-Sprayer	3.6	ppb
38200-153-S6	Food Service Sink-Hand Sink	13.9	ppb
38200-102-S1	Sink in Work Room 102	7.4	ppb
38200-102-S2	Sink in Work Room 102	10.7	ppb
38200-192H-S1	Hallway Sink across from Classroom W1	1.8	ppb
38200-192H-SWB1	Hallway Sink with Bubbler across from Classroom W1	2.3	ppb
38200-192H-S2	Hallway Sink across from Classroom W1	3.7	ppb
38200-192H-SWB2	Hallway Sink with Bubbler across from Classroom W1	1.5	ppb
38200-175H-SWB	Hallway Sink with Bubbler across near Classroom N4	1.6	ppb
38200-175H-S	Hallway Sink near Classroom N4	5.0	ppb
38200-165H-S	Hallway Sink across from Classroom S3	2.0	ppb
38200-165H-SWB	Hallway Sink with Bubbler across from Classroom S3	0.8	ppb
38200-S1-S	Sink in Teacher's Lounge	5.9	ppb
38200-138H-DF	Hallway Drinking Fountain near Art Room	8.2	ppb
38200-139-S1	Art Room Sink	19.6	ppb
38200-139-S2	Art Room Sink	5.3	ppb
38200-142H-S	Hallway Sink near Library	1.6	ppb
38200-142H-SWB	Hallway Sink with Bubbler near Library	1.7	ppb