

Swanson Elementary - Sampled 7/12/16			
CustomerSampleNumber	Description	Lead Result	Unit
43500-158-S	Sink in Clinic	2.4	ppb
43500-158-SWB	Sink with Bubblers in Clinic	0.8	ppb
43500-158A-S	Sink in Clinic Restroom	4.4	ppb
43500-160H-DFL	Drinking Fountain in Hallway across from Clinic/Left	18.5	ppb
43500-160H-DFR	Drinking Fountain in Hallway across from Clinic/Right	10.5	ppb
43500-153-S	Sink in Workroom near Kitchen	2.1	ppb
43500-153-SWB	Sink with Bubblers in Workroom near Kitchen	1.3	ppb
43500-124B-S1	Food Service Sink - Hand Sink	15.0	ppb
43500-124B-S2	Food Service Sink - Food Prep Sink	10.5	ppb
43500-124B-S3	Food Service Sink - Wash/Rinse Sink	10.0	ppb
43500-124B-S4	Food Service Sink - Rinse/Sanitize Sink	11.1	ppb
43500-101-SWB	Sink with Bubblers in Room 1	1.9	ppb
43500-101-S	Sink in Room 1	9.2	ppb
43500-102-S	Sink in Room 2	8.0	ppb
43500-102-SWB	Sink with Bubblers in Room 2	2.2	ppb
43500-174H-DFL	Drinking Fountain in Hallway near Gym/Left	8.8	ppb
43500-174H-DFR	Drinking Fountain in Hallway near Gym/Right	6.9	ppb
43500-103-S	Sink in Room 3	4.2	ppb
43500-103-SWB	Sink with Bubblers in Room 3	1.0	ppb
43500-104-S	Sink in Room 4	3.3	ppb
43500-104-SWB	Sink with Bubblers in Room 4	1.0	ppb
43500-105-S	Sink in Room 5	4.1	ppb
43500-105-SWB	Sink with Bubblers in Room 5	0.9	ppb
43500-106-S	Sink in Room 6	2.9	ppb
43500-106-SWB	Sink with Bubblers in Room 6	0.6	ppb
43500-192H-DF	Drinking Fountain in Hallway near Room 28	17.1	ppb
43500-108-S	Sink in Computer Lab - Room 8	20.4	ppb
43500-108-SWB	Sink with Bubblers in Computer Lab - Room 8	7.1	ppb
43500-028-S	Sink in Room 28	3.7	ppb
43500-028-SWB	Sink with Bubblers in Room 28	7.0	ppb
43500-109-S	Sink in Room 9	106.5	ppb
43500-109-SWB	Sink with Bubblers in Room 9	2.1	ppb
43500-027-S	Sink in Room 27	5.7	ppb
43500-027-SWB	Sink with Bubblers in Room 27	3.0	ppb
43500-026-S	Sink in Room 26	5.8	ppb
43500-026-SWB	Sink with Bubblers in Room 26	1.2	ppb
43500-111-S	Sink in Room 11	2.5	ppb
43500-111-SWB	Sink with Bubblers in Room 11	2.3	ppb
43500-036-S	Sink in Room 36	1.9	ppb
43500-036-SWB	Sink with Bubblers in Room 36	0.9	ppb
43500-113-S	Sink in Kindergarten Room 13	5.2	ppb
43500-113-SWB	Sink with Bubblers in Kindergarten Room 13	13.5	ppb

43500-029-S	Sink in Room 29	3.3	ppb
43500-029-SWB	Sink with Bubblers Room 29	3.0	ppb
43500-030-S	Sink in Room 30	47.7	ppb
43500-030-SWB	Sink with Bubblers in Room 30	1.6	ppb
43500-031-S	Sink in Room 31	6.4	ppb
43500-031-SWB	Sink with Bubblers in Room 31	1.1	ppb
43500-115-S	Sink in Library Workroom	4.5	ppb
43500-033-S	Sink in Room 33	4.1	ppb
43500-033-SWB	Sink with Bubblers in Room 33	0.9	ppb
43500-032-S	Sink in Room 32	3.5	ppb
43500-032-SWB	Sink with Bubblers in Room 32	2.0	ppb
43500-034-S	Sink in Room 34	1.5	ppb
43500-034-SWB	Sink with Bubblers in Room 34	2.8	ppb
43500-035-S	Sink in Room 35	4.1	ppb
43500-035-SWB	Sink with Bubblers in Room 35	6.0	ppb
43500-142-S1	Sink in Art Room (Room 42)	1.4	ppb
43500-142-S2	Sink in Art Room (Room 42)	3.9	ppb
43500-142-S3	Sink in Art Room (Room 42)	5.3	ppb
43500-142-S4	Sink in Art Room (Room 42)	6.5	ppb
43500-142-S5	Sink in Art Room (Room 42)	6.0	ppb
43500-037-S	Sink in Reading Room 37	31.2	ppb
43500-037-SWB	Sink with Bubblers in Reading Room 37	1.6	ppb
43500-185H-DF	Drinking Fountain in Hallway near Room 37	4.7	ppb
43500-114-S	Sink in Kindergarten Room 14	137.6	ppb
43500-114-SWB	Sink with Bubblers in Kindergarten Room 14	1.1	ppb
43500-112-S	Sink in Kindergarten Room 12	30.7	ppb
43500-112-SWB	Sink with Bubblers in Kindergarten Room 12	1.2	ppb
43500-110-S	Sink in Book Room (Room 10)	49.8	ppb
43500-110-SWB	Sink with Bubblers in Book Room (Room 10)	67.8	ppb
43500-170-S	Sink in Teacher's Lounge	3.9	ppb
43500-REC-120-DF	Drinking Fountain in Temp REC-120 (Temp 3)	88.8	ppb
43500-R1-095-S	Sink in Temp R1-095 (Temp 1)	1.3	ppb
43500-REC-119-DF	Drinking Fountain in Temp REC-119 (Temp 2)	2.6	ppb