

Ute Meadows Elementary School - Sampled 6/8/16			
CustomerSampleNumber	Description	Lead Result	Units
44300-120-S	Sink in Office Workroom	8.7	ppb
44300-118-S	Sink in Clinic	4.2	ppb
44300-129-S	Sink in Teacher's Lounge	0.8	ppb
44300-Art-S1	Sink in Art Room	6.8	ppb
44300-Art-S2	Sink in Art Room	34.9	ppb
44300-Art-S3	Sink in Art Room	69.7	ppb
44300-Art-S4	Sink in Art Room	42.1	ppb
44300-106-DF	Drinking Fountain Near Cafeteria	0.2	ppb
44300-108-S1	Food Service Sink	7.7	ppb
44300-108-S2	Food Service Sink	2.4	ppb
44300-C15-DF	Drinking Fountain in C-Pod Near Room C-7	17.5	ppb
44300-C10-S	Sink in C-Pod	1.1	ppb
44300-C14-DF	Drinking Fountain in C-Pod Near Room C-1	3.5	ppb
44300-B15-DF	Drinking Fountain in B-Pod	2.0	ppb
44300-B10-S	Sink in B-Pod	0.4	ppb
44300-B14-DF	Drinking Fountain in B-Pod	7.4	ppb
44300-A15-DF	Drinking Fountain in A-Pod	1.3	ppb
44300-A10-S	Sink in A-Pod	0.6	ppb
44300-A14-DF	Drinking Fountain in A-Pod	5.2	ppb
44300-133-S	Sink in Library Workroom	6.6	ppb
44300-126H-DF	Hallway Drinking Fountain	3.1	ppb
44300-2K-SWB	Sink with Bubbler in Kindergarten Room 2	8.1	ppb
44300-1K-SWB	Sink with Bubbler in Kindergarten Room 1	5.9	ppb
44300-RE-037-DF	Drinking Fountain in Temp RE-037	1.1	ppb
44300-108-53	Food Service Sink	3.1	ppb
44300-RE-037-S1	Sink in Temp RE-037	0.9	ppb
44300-RE-037-S2	Sink in Temp RE-037	0.9	ppb