

Van Arsdale Elementary School - Sampled 9/1/16				Resampled** 11/9/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Unit
44200-A-1-S	Sink in Classroom A-1	12.5	ppb		
44200-A-4-S	Sink in Classroom A-4	19.1	ppb	0.2	ppb
44200-A-4H-DFL	Hallway Drinking Fountain across from Classroom A-4/Left	0.2	ppb		
44200-A-6-S	Sink in Classroom A-6	5.4	ppb		
44200-B-1-S	Sink in Classroom B-1	6.4	ppb		
44200-B-4-S	Sink in Classroom B-4	23.0	ppb	0.2	ppb
44200-B-4H-DFL	Hallway Drinking Fountain across from Classroom B-4/Left	2.5	ppb		
44200-B-4H-DFR	Hallway Drinking Fountain across from Classroom B-4/Right	0.2	ppb		
44200-B-6-S	Sink in Classroom B-6	22.5	ppb	0.2	ppb
44200-132H-DFL	Hallway Drinking Fountain outside of Cafeteria/Left	0.2	ppb		
44200-132H-DFR	Hallway Drinking Fountain outside of Cafeteria/Right	0.4	ppb		
44200-124-S1	Food Service Sink-Food Warmer Faucet	4.2	ppb		
44200-124-S2	Food Service Sink-Wash	10.1	ppb		
44200-124-S3	Food Service Sink-Rinse	1.7	ppb		
44200-124-S4	Food Service Sink-Prep Sink	3.5	ppb		
44200-124-S5	Food Service Sink-Hand Sink	4.0	ppb		
44200-120-S1	Food Service Sink-Sprayer	4.5	ppb		
44200-120-S2	Food Service Sink	1.1	ppb		
44200-114-S	Sink in Main Office Area	20.7	ppb	1.0	ppb
44200-107-S	Sink in Main Office Work Room	4.0	ppb		
44200-109-S	Sink in Clinic	140.4	ppb		Repairs Pending
44200-182-S	Sink in Teacher's Lounge	3.4	ppb		
44200-C-1-S	Sink in Classroom C-1	9.3	ppb		
44200-C-3H-DF	Hallway Drinking Fountain across from Classroom C-3	0.2	ppb		
44200-C-4-S	Sink in Office C-4	7.6	ppb		
44200-C-4H-DF	Hallway Drinking Fountain across from Classroom C-5	0.3	ppb		
44200-C-6-S	Sink in Classroom C-6	3.9	ppb		
44200-D-6-S	Sink in Classroom D-6	4.1	ppb		
44200-D-4H-DF	Hallway Drinking Fountain across from Classroom D-6	0.2	ppb		
44200--D-3H-DF	Hallway Drinking Fountain across from D-4	3.1	ppb		
44200-D-4-S	Sink in Classroom D-4	13.8	ppb		
44200-D-1-S	Sink in Kindergarten Classroom D-1	2.5	ppb		
44200-ART-S1	Art Room Sink	5.7	ppb		
44200-ART-S2	Art Room Sink	5.8	ppb		
44200-R1-220-DF	Drinking Fountain in TEMP R1-220	7.7	ppb		
44200-R1-071-DF	Drinking Fountain in TEMP R1-071	5.4	ppb		
44200-R1-036-DF	Drinking Fountain in TEMP R1-036	2.3	ppb		
44200-107-WC	Water Cooler in Room 107	<0.1* ***	ppb		
44200-A-4H-DFR	Hallway Drinking Fountain across from Classroom A4/Right	0.1***	ppb		
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.					
** Resampling results after elevated fixtures were repaired, or removed and replaced.					
*** This fixture was sampled on 11/23/16.					