

Vanderhoof Elementary - Sampled 7/13/16				Resampled** 8/9/16, 8/30/16, 11/16/16	
CustomerSampleNumber	Description	Lead Result	Unit	Lead Result	Units
44000-114-DF1	Drinking Fountain by Gym near PE Storage Area	19.0	ppb	8.2	ppb
44000-114-DF2	Drinking Fountain by Gym on side opposite PE Storage Area	5.6	ppb		
44000-109-S	Sink in Teacher's Lounge	2.6	ppb		
44000-135-S	Sink in Classroom 135 (W2)	3.3	ppb		
44000-135-SWB	Sink with Bubbler in Classroom 135 (W2)	1.7	ppb		
44000-132R-SWB	Sink with Bubbler by Restrooms near Classroom 134 (W4)	1.0	ppb		
44000-132R-S	Sink by Restrooms near Classroom 134 (W4)	4.6	ppb		
44000-C2-S	Sink in Classroom 148 (C2)	7.1	ppb		
44000-C2-SWB	Sink with Bubbler in Classroom 148 (C2)	10.9	ppb		
44000-108AH-DF	Drinking Fountain in Hallway across from Room 162 (N5)	0.2	ppb		
44000-109AH-S	Sink in Hallway across from Room 162 (N5)	1.9	ppb		
44000-C5-S	Sink in Classroom 151 (C5)	4.4	ppb		
44000-C5-SWB	Sink with Bubbler in Classroom 151 (C5)	2.6	ppb		
44000-119R-SWB	Sink with Bubbler by Restrooms near Classroom 139 (E4)	1.2	ppb		
44000-119R-S	Sink by Restrooms near Classroom 139 (E4)	1.3	ppb		
44000-E2-S	Sink in Classroom 138 (E2)	2.3	ppb		
44000-E2-SWB	Sink with Bubbler in Classroom 138 (E2)	2.8	ppb		
44000-168-S1	Sink in Art Room	13.4	ppb		
44000-168-S2	Sink in Art Room	2.6	ppb		
44000-168-S3	Sink in Art Room	0.3	ppb		
44000-168-S4	Sink in Art Room	0.4	ppb		
44000-122-S1	Food Service Sink - Hand Sink	6.1	ppb		
44000-122-S2	Food Service Sink - Sanitize/Rinse Sink	7.3	ppb		
44000-122-S3	Food Service Sink - Rinse/Wash Sink	36.2	ppb	7.2	ppb
44000-122-S4	Food Service Sink - Food Prep Sink	59.8	ppb	Fixture Removed	
44000-122-S5	Food Service Sink - Food Prep Sink	17.0	ppb	4.8	ppb
44000-121-S	Sink in Cafeteria	4.2	ppb		
44000-121-SWB	Sink with Bubbler in Cafeteria	1.0	ppb		
44000-X100H-DFL	Drinking Fountain in Hallway near Restrooms by Cafeteria/Left	5.2	ppb		
44000-X100H-DFR	Drinking Fountain in Hallway near Restrooms by Cafeteria/Right	5.6	ppb		
44000-125-S	Sink in Clinic	1.8	ppb		
44000-120-S1	Sink in Kindergarten Room 120 (on left as you enter room)	4.6	ppb		
44000-120-SWB1	Sink with Bubbler in Kindergarten Room 120 (on left as you enter room)	7.5	ppb		
44000-120-S2	Sink in Kindergarten Room 120 (on right as you enter room)	7.9	ppb		
44000-120-SWB2	Sink with Bubbler in Kindergarten Room 120 (on right as you enter room)	2.7	ppb		
44000-R1-234-DF	Drinking Fountain in Temporary Classroom R1-234	1.0	ppb		
44000-R1-233-DF	Drinking Fountain in Temporary Classroom R1-233	1.2	ppb		
44000-R1-053-DF	Drinking Fountain in Temporary Classroom R1-053	8.2	ppb		

** Resampling results after elevated fixtures were removed and replaced.