

Vivian Elementary School - Sampled 6/30/16			
CustomerSampleNumber	Description	Lead Result	Units
44500-112-DF	Drinking Fountain in Cafeteria	4.4	ppb
44500-114-S1	Food Services-Hand Sink	1.2	ppb
44500-114-S2	Food Services-Sanitize/Rinse/Wash Sink	2.9	ppb
44500-18-SWB	Sink with Bubblers in Classroom 18	3.9	ppb
44500-18-S	Sink in Classroom 18	16.1	ppb
44500-20-S	Sink in Classroom 20	6.3	ppb
44500-20-SWB	Sink with Bubblers in Classroom 20	3.3	ppb
44500-19-S	Sink in Classroom 19	5.6	ppb
44500-19-SWB	Sink with Bubblers in Classroom 19	2.5	ppb
44500-17-S	Sink in Classroom 17	7.1	ppb
44500-17-SWB	Sink with Bubblers in Classroom 17	5.3	ppb
44500-124-S	Sink in Teacher's Lounge	0.7	ppb
44500-10-S	Sink in Classroom 10	7.4	ppb
44500-10-SWB	Sink with Bubblers in Classroom 10	1.7	ppb
44500-12-S1	Sink in Art Room/Left	55.3	ppb
44500-12-S2	Sink in Art Room/Right	28.3	ppb
44500-14-SWB	Sink with Bubblers in Classroom 14	0.8	ppb
44500-14-S	Sink in Classroom 14	1.9	ppb
44500-105H-DF	Hallway Drinking Fountain near Classroom 16	5.0	ppb
44500-16-S	Sink in Classroom 16	19.5	ppb
44500-16-SWB	Sink with Bubblers in Classroom 16	51.4	ppb
44500-15-SWB	Sink with Bubblers in Classroom 15	15.2	ppb
44500-15-S	Sink in Classroom 15	37.6	ppb
44500-13-SWB	Sink with Bubblers in Classroom 13	10.0	ppb
44500-12BH-DF	Hallway Drinking Fountain Near Art Room	0.2	ppb
44500-5-S	Sink in Classroom 5	2.4	ppb
44500-5-SWB	Sink with Bubblers in Classroom 5	0.9	ppb
44500-4-S	Sink in Classroom 4	0.6	ppb
44500-4-SWB	Sink with Bubblers in Classroom 4	0.8	ppb
44500-3-S	Sink in Classroom 3	0.5	ppb
44500-3-SWB	Sink with Bubblers in Classroom 3	1.2	ppb
44500-2-S	Sink in Classroom 2	0.9	ppb
44500-2-SWB	Sink with Bubblers in Classroom 2	2.8	ppb
44500-1-S	Sink in Kindergarten Classroom 1	1.3	ppb
44500-1-SWB	Sink with Bubblers in Kindergarten Classroom 1	1.1	ppb
44500-107H-DFL	Hallway Drinking Fountain Near Classroom 7/Left	7.1	ppb
44500-107H-DFR	Hallway Drinking Fountain Near Classroom 7/Right	1.9	ppb
44500-9C-SWB	Sink with Bubblers in Classroom 9C	8.0	ppb
44500-9C-S	Sink in Classroom 9C	1.3	ppb
44500-7-S	Sink in Classroom 7	12.5	ppb