

Weber Elementary - Sampled 7/13/16			
CustomerSampleNumber	Description	Lead Result	Unit
45200-10-S	Sink in Teacher's Lounge	0.9	ppb
45200-61XH-DF	Drinking Fountain in Hallway across from Book Room (Room 30)	0.4	ppb
45200-60XH-DFL	Drinking Fountain in Hallway across from Classroom 19/Left	0.7	ppb
45200-60XH-DFR	Drinking Fountain in Hallway across from Classroom 19/Right	1.2	ppb
45200-B4H-DFL	Drinking Fountain in Hallway across from Classroom 15/Left	0.4	ppb
45200-B4H-DFR	Drinking Fountain in Hallway across from Classroom 15/Right	1.0	ppb
45200-37H-S	Sink in Hallway between Classrooms 21 and 25	3.3	ppb
45200-64XH-DFL	Drinking Fountain in Hallway just outside Classroom 24/Left	0.1	ppb
45200-64XH-DFR	Drinking Fountain in Hallway just outside Classroom 24/Right	0.1	ppb
45200-44-S1	Food Service - Hand Sink	3.0	ppb
45200-44-S2	Food Service - Hose Sprayer	8.3	ppb
45200-44-S3	Food Service - Sanitize/Rinse Sink	8.7	ppb
45200-44-S4	Food Service - Rinse/Wash Sink	8.1	ppb
45200-44-S5	Food Service - Food Prep Sink (on left)	11.5	ppb
45200-44-S6	Food Service - Food Prep Sink (on right)	1768.3	ppb
45200-45-DF	Drinking Fountain in Cafeteria	0.6	ppb
45200-45-S	Sink in Cafeteria	6.4	ppb
45200-66H-DF	Drinking Fountain in Hallway near Room 23	< 0.1 *	ppb
45200-65H-DF	Drinking Fountain in Hallway near Art Room	0.1	ppb
45200-28-S1	Sink in Art Room	3.2	ppb
45200-28-S2	Sink in Art Room	1.8	ppb
45200-76X-S	Sink in Office (Room 76X) near Music Room	4.1	ppb
45200-51H-DF	Drinking Fountain in Hallway near Gym	0.5	ppb
45200-52X-S	Sink in Clinic	1.8	ppb
45200-63XH-S1	Sink in Hallway near Principal's Office	0.9	ppb
45200-63XH-DFL	Drinking Fountain in Hallway across from Classroom 5/Left	0.3	ppb
45200-63XH-DFR	Drinking Fountain in Hallway across from Classroom 5/Right	0.5	ppb
45200-63XH-S2	Sink in Hallway across from Classroom 5	1.1	ppb
45200-63XH-S3	Sink in Hallway across from Classroom 2	8.0	ppb
45200-170H-DFL	Drinking Fountain in Hallway across from Classroom 1/Left	1.0	ppb
45200-170H-DFR	Drinking Fountain in Hallway across from Classroom 1/Right	0.7	ppb
45200-R1-154-DF	Drinking Fountain in Temporary Classroom R1-154	9.0	ppb
45200-R1-153-DF	Drinking Fountain in Temporary Classroom R1-153	14.7	ppb

\* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.