

West Jefferson Elementary School - Sampled 8/20/16				Resampled** 12/7/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
46000-B108-S	Sink in Library Work Room	80.3	ppb	2.3	ppb
46000-002-S	Sink in Classroom 002	4.7	ppb		
46000-002-SWB	Sink with Bubblers in Classroom 002	3.7	ppb		
46000-003-S	Sink in Classroom 003	4.2	ppb		
46000-003-SWB	Sink with Bubblers in Classroom 003	1.1	ppb		
46000-004-S	Sink in Classroom 004	3.4	ppb		
46000-004-SWB	Sink with Bubblers in Classroom 004	1.0	ppb		
46000-A112H-DF	Hallway Drinking Fountain in Pod A	1.6	ppb		
46000-005-SWB	Sink with Bubblers in Classroom 005	0.7	ppb		
46000-006-SWB	Sink with Bubblers in Classroom 006	1.2	ppb		
46000-007-S	Sink in Classroom 007	2.8	ppb		
46000-007-SWB	Sink with Bubblers in Classroom 007	1.0	ppb		
46000-008-S	Sink in Classroom 008	2.7	ppb		
46000-008-SWB	Sink with Bubblers in Classroom 008	0.6	ppb		
46000-009-S	Sink in Classroom 009	2.0	ppb		
46000-009-SWB	Sink with Bubblers in Classroom 009	1.1	ppb		
46000-010-S	Sink in Classroom 010	1.9	ppb		
46000-010-SWB	Sink with Bubblers in Classroom 010	1.9	ppb		
46000-011-S	Sink in Classroom 011	1.8	ppb		
46000-011-SWB	Sink with Bubblers in Classroom 011	0.9	ppb		
46000-B120H-DF	Hallway Drinking Fountain in Pod B	1.2	ppb		
46000-012-S	Sink in Classroom 012	5.1	ppb		
46000-012-SWB	Sink with Bubblers in Classroom 012	1.2	ppb		
46000-013-S	Sink in Classroom 013	2.5	ppb		
46000-013-SWB	Sink with Bubblers in Classroom 013	0.6	ppb		
46000-014-S	Sink in Classroom 014	2.2	ppb		
46000-014-SWB	Sink with Bubblers in Classroom 014	0.5	ppb		
46000-015-S	Sink in Kindergarten Classroom 015	3.8	ppb		
46000-015-SWB	Sink with Bubblers in Kindergarten Classroom 015	0.6	ppb		
46000-016-S	Sink in Classroom 016	1.0	ppb		
46000-016-SWB	Sink with Bubblers in Classroom 016	0.4	ppb		
46000-C122H-DF	Hallway Drinking Fountain in Pod C	1.9	ppb		
46000-C130-S1	Art Room Sink	7.0	ppb		
46000-C130-S2	Art Room Sink	1.9	ppb		
46000-D118-S1	Food Service Sink-Hand Sink	10.5	ppb		
46000-D118-S2	Food Service Sink-Sprayer	3.2	ppb		
46000-D118-S3	Food Service Sink-Rinse	2.8	ppb		
46000-D118-S4	Food Service Sink-Sanitize	5.6	ppb		
46000-D118-S5	Food Service Sink-Food Prep	2.7	ppb		
46000-D118-S6	Food Service Sink-Hand Sink	9.2	ppb		
46000-D118-S7	Food Service Sink-Sprayer	2.9	ppb		
46000-D108H-DF	Hallway Drinking Fountain in Pod D	2.2	ppb		
46000-D109-S	Sink in Music Room	2.1	ppb		
46000-C104-S	Sink in Teacher's Lounge	2.5	ppb		
46000-C105-S	Sink in Main Office Work Room	6.6	ppb		
46000-C105-SWB	Sink with Bubblers in Main Office Work Room	1.7	ppb		
46000-C112-S	Sink in Clinic	6.9	ppb		
46000-C112-SWB	Sink with Bubblers in Clinic	0.6	ppb		
46000-B108-SWB	Sink with Bubblers in Library Workroom	1.6***	ppb		
46000-001-S	Sink in Kindergarten Classroom 001	1.4***	ppb		
46000-001-SWB	Sink with Bubblers in Kindergarten Classroom 001	0.7***	ppb		

** Resampling results after elevated fixtures were removed and replaced.

*** This fixture was sampled on 12/7/16.