

Windy Peak OELS - Sampled 11/23/16			
CustomerSampleNumber	Description	Lead Result	Unit
59200-EastRes-Kitchen-S	Sink in East Residence Kitchen	2.1	ppb
59200-EastRes-Bath-S1	Sink on Left in East Residence Restroom	3.9	ppb
59200-EastRes-Bath-S2	Sink on Right in East Residence Restroom	18.0	ppb
59200-EastDuplex-Kitchen-S	Sink in East Duplex Kitchen	2.9	ppb
59200-EastDuplex-Bath-S	Sink in East Duplex Restroom	1.7	ppb
59200-M and B-Bath1-S	Sink in Restroom on Left in Maxwell Boegel Bldg	5.0	ppb
59200-M and B-Bath2-S	Sink in Restroom on Right in Maxwell Boegel Bldg	0.7	ppb
59200-Lodge Pole-Bath1-S1	Sink on Left in Restroom on Left in Lodgepole Bldg	2.8	ppb
59200-Lodge Pole-Bath1-S2	Sink on Right in Restroom on Left in Lodgepole Bldg	1.3	ppb
59200-Lodge Pole-Kitchen-S	Sink in Kitchen in Lodgepole Bldg	1.1	ppb
59200-Lodge Pole-Bath2-S	Sink in Restroom on Right in Lodgepole Bldg	3.5	ppb
59200-Main Office-S	Sink in Main Office	5.4	ppb
59200-Main Office-Bath-S	Sink in Main Office Restroom	30.1	ppb
59200-Astronomy-DF	Drinking Fountain in Astronomy Bldg	1.0	ppb
59200-Astronomy-WB-S	Sink in Women's Restroom in Astronomy Bldg	0.6	ppb
59200-Astronomy-MB-S	Sink in Men's Restroom in Astronomy Bldg	0.8	ppb
59200-Columbine-Bath1-S	Sink in Restroom on Left in Columbine Bldg	0.5	ppb
59200-Columbine-Bath2-S	Sink in Restroom on Right in Columbine Bldg	0.5	ppb
59200-Juniper-S	Sink in Juniper Bldg	16.6	ppb
59200-Castleview-S	Sink in Castleview Bldg	11.9	ppb
59200-Central Shower-Boys-S1	Sink in Boys Central Shower	1.5	ppb
59200-Central Shower-Boys-S2	Sink in Boys Central Shower	1.0	ppb
59200-Central Shower-Boys-S3	Sink in Boys Central Shower	1.1	ppb
59200-Central Shower-Boys-S4	Sink in Boys Central Shower	0.8	ppb
59200-Central Shower-Girls-S1	Sink in Girls Central Shower	0.7	ppb
59200-Central Shower-Girls-S2	Sink in Girls Central Shower	0.7	ppb
59200-Central Shower-Girls-S3	Sink in Girls Central Shower	0.7	ppb
59200-Central Shower-Girls-S4	Sink in Girls Central Shower	0.9	ppb
59200-West Duplex-Kitchen-S	Sink in West Duplex Kitchen	1.5	ppb
59200-West Duplex-Bath-S	Sink in West Duplex Restroom	2.3	ppb
59200-Dining Hall-Kitchen-S1	Hand Sink in Dining Hall Kitchen	0.6	ppb
59200-Dining Hall-Kitchen-S2	Sprayer in Dining Hall Kitchen	0.3	ppb
59200-Dining Hall-Kitchen-S3	Faucet on Left over 3-Basin Sink in Dining Hall Kitchen	2.3	ppb
59200-Dining Hall-Kitchen-S4	Faucet on Right over 3-Basin Sink in Dining Hall Kitchen	3.4	ppb
59200-Dining Hall-WBFS	Water Bottle Filling Station in Dining Hall	1.4	ppb
59200-Dining Hall-Entrance-DF	Drinking Fountain in Dining Hall Entrance	1.6	ppb
59200-Geology-DF	Drinking Fountain in Geology Classroom in Barn	35.1	ppb
59200-Custodial-Bath-S	Sink in Restroom in Custodial Storage	14.3	ppb
59200-Spigot	Spigot near Clinic	12.5	ppb
59200-Clinic-S	Sink in Clinic	0.8	ppb
59200-Clinic-Bath-S	Sink in Clinic Restroom	1.0	ppb
59200-LMC-DF	Drinking Fountain in Library	19.2	ppb
59200-Clinic-DF	Drinking Fountain in Clinic	18.8	ppb
59200-InternOffice-S	Sink in Storage Area near the Generator Shed	17.6	ppb
59200-Lodge-Bath1-S	Sink in Restroom on left in Main Lodge	5.8	ppb
59200-Lodge-Kitchen-S	Kitchen Sink in Main Lodge	1.5	ppb
59200-Lodge-Bath2-S	Sink in middle Restroom in Main Lodge	1.8	ppb
59200-Lodge-Bath3-S	Sink in Restroom on right in Main Lodge	8.1	ppb
59200-Central Showers-Staff W-S	Sink in Staff Central Shower/Women's	4.0	ppb
59200-Central Showers-Staff M-S	Sink in Staff Central Shower/Men's	12.3	ppb